

Part III Form 2

Section 11. ANNUAL REPORT.

Drinking-Water System Number:	220003537
Drinking-Water System	David Street Water Treatment Plant and Distribution System
Drinking-Water System Owner:	City of Greater Sudbury
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	From 2009-01-01 To 2009-12-31

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>www.greatersudbury.ca TDS-Engineering Department</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Number of Interested Authorities you report to: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Wanapitei Water Treatment Plant and Distribution System	210001111

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes No

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
 - Public access/notice via Government Office
 - Public access/notice via a newspaper
 - Public access/notice via Public Request
 - Public access/notice via a Public Library/Citizen Service Centre
 - Public access/notice via other method
-

Describe your Drinking-Water System

The David St. WTP is a surface water plant which draws water from Ramsey Lake. Proportionally, the plant services approximately 40% of Sudbury, however, most of the water produced at the David St. WTP is normally delivered to the south, west and downtown areas of Sudbury. The plant is over 100 years old and has undergone numerous upgrades to meet changing needs and regulations. The plant is in full treatment compliance with O. Reg. 170/03 with the upgrades. Treatment incorporated is in the form of membrane ultrafiltration, disinfection by chlorination, Ultra-Violet irradiation, fluoridation, pH adjustment and corrosion control with a polyphosphate. The distribution system supplied by the David Street WTP includes parts of downtown Sudbury, the South End and the West End of Sudbury. In addition, the Ellis Reservoir is part of the distribution network for Sudbury.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite UN#1791, Hydrofluosilicic Acid UN#1778, Polyphosphate, Sodium Hydroxide UN#1824, Sodium Bisulfate UN#2693, Citric Acid UN#3625

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Ramsey Lake outfall engineering: \$40,000.00

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
2009/02/13	Total Coliform	8	cfu	Resample/Re-test;	2009/02/17
2009/04/16	UV	0	mj/cm ²	Disinfectant restored/increased;	2009/04/16
2009/06/04	UV	9	mj/cm ²	Disinfectant restored/increased;	2009/06/04
2009/08/05	Sodium	53.2	mg/L	Resample	2009/08/10
2009/08/14	Total Coliform	67	cfu	Resample/Re-test;	2009/08/17
2009/11/02	Total Coliform	7	cfu	Resample/Re-test	2009/11/04
2009/11/05	Total Coliform	3	cfu	Resample/re-test	2009/11/06

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw: RAMSEY LAKE					
	53	0 to 39	0 to 62		
Treated: SUDBURY (DAVID ST) Water Treatment Plant					
	155	0 to 0	0 to 0	154	0 to 230
Distribution					
	1,622	0 to 0	0 to 67	350	0 to 1020

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #) - (max #)
Chlorine Residual Distribution System	8,760	0.37 - 3.32 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

SUDBURY (DAVID ST) Water Treatment Plant

Turbidity	8,760	0.01 - 0.90	NTU
Chlorine	8,760	0.71 - 2.40	mg/L
Fluoride (If the DWS provides fluoridation)	8,760	0.03 - 1.22	mg/L

NOTE: Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Lead	2009/12/10	0.001	mg/L	No

SUDBURY (DAVID ST) Water Treatment Plant

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2009/12/07	0.0005	mg/L	No
Arsenic	2009/12/07	0.0019	mg/L	No
Barium	2009/12/07	0.0147	mg/L	No
Boron	2009/12/07	0.0092	mg/L	No
Cadmium	2009/12/07	0.0001	mg/L	No
Chromium	2009/12/07	0.001	mg/L	No
Mercury	2009/12/07	0.00001	mg/L	No
Selenium	2009/12/07	0.001	mg/L	No
Uranium	2009/12/07	0.001	mg/L	No
Fluoride	2004/01/19	0.1	mg/L	No
Nitrate	2009/03/17	0.10	mg/L	No
	2009/06/16	0.10	mg/L	No
	2009/09/15	0.10	mg/L	No
	2009/12/15	0.10	mg/L	No
Nitrite	2009/03/17	0.05	mg/L	No
	2009/06/16	0.05	mg/L	No
	2009/09/15	0.05	mg/L	No
	2009/12/15	0.05	mg/L	No
Sodium	2006/10/23	48.70	mg/L	Yes

Summary of lead testing under Schedule 15.1 during this reporting period.

Location Type	Number of Samples	Range of Lead Results (min#) - (max#)	Number of Exceedances
Plumbing	100	0.001 - 0.0146 mg/L	1
Distribution	20	0.001 - 0.001 mg/L	0

Summary of Organic parameters sampled during this reporting period or most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)	2009	0.0724	mg/L	No

SUDBURY (DAVID ST) Water Treatment Plant

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2009/12/07	0.00058	mg/L	No
Aldicarb	2009/12/07	0.00056	mg/L	No
Aldrin + Dieldrin	2009/12/07	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2009/12/07	0.0009	mg/L	No
Azinphos-methyl	2009/12/07	0.00035	mg/L	No
Bendiocarb	2009/12/07	0.0011	mg/L	No
Benzene	2009/12/07	0.00025	mg/L	No
Benzo(a)pyrene	2009/12/07	0.0000057	mg/L	No
Bromoxynil	2009/12/07	0.0005	mg/L	No
Carbaryl	2009/12/07	0.0011	mg/L	No
Carbofuran	2009/12/07	0.0011	mg/L	No
Carbon Tetrachloride	2009/12/07	0.00025	mg/L	No
Chlordane (Total)	2009/12/07	0.000004	mg/L	No
Chlorpyrifos	2009/12/07	0.00035	mg/L	No
Cyanazine	2009/12/07	0.00047	mg/L	No
Diazinon	2009/12/07	0.00035	mg/L	No
Dicamba	2009/12/07	0.0002	mg/L	No
1,2-Dichlorobenzene	2009/12/07	0.00025	mg/L	No
1,4-Dichlorobenzene	2009/12/07	0.00025	mg/L	No
(DDT) + metabolites	2009/12/07	0.000005	mg/L	No
1,2-Dichloroethane	2009/12/07	0.00025	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2009/12/07	0.00025	mg/L	No
Dichloromethane	2009/12/07	0.00025	mg/L	No
2-4 Dichlorophenol	2009/12/07	0.001	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2009/12/07	0.0002	mg/L	No
Diclofop-methyl	2009/12/07	0.0002	mg/L	No
Dimethoate	2009/12/07	0.00023	mg/L	No
Dinoseb	2009/12/07	0.00005	mg/L	No
Diquat	2009/12/07	0.007	mg/L	No
Diuron	2009/12/07	0.0056	mg/L	No
Glyphosate	2009/12/07	0.02	mg/L	No
Heptachlor + Heptachlor Epoxide	2009/12/07	0.000004	mg/L	No
Linadane (Total)	2009/12/07	0.00000034	mg/L	No

Malathion	2009/12/07	0.00023	mg/L	No
Methoxychlor	2009/12/07	0.00000092	mg/L	No
Metolachlor	2009/12/07	0.00023	mg/L	No
Metribuzin	2009/12/07	0.00023	mg/L	No
Monochlorobenzene	2009/12/07	0.00025	mg/L	No
Paraquat	2009/12/07	0.001	mg/L	No
Parathion	2009/12/07	0.00035	mg/L	No
Pentachlorophenol	2009/12/07	0.001	mg/L	No
Phorate	2009/12/07	0.00035	mg/L	No
Picloram	2009/12/07	0.00005	mg/L	No
Polychlorinated Biphenyls(PCB)	2009/12/07	0.0000032	mg/L	No
Prometryne	2009/12/07	0.00023	mg/L	No
Simazine	2009/12/07	0.00058	mg/L	No
Temephos	2009/12/07	0.016	mg/L	No
Terbufos	2009/12/07	0.00035	mg/L	No
Tetrachloroethylene	2009/12/07	0.00025	mg/L	No
2,3,4,6-Tetrachlorophenol	2009/12/07	0.001	mg/L	No
Triallate	2009/12/07	0.00058	mg/L	No
Trichloroethylene	2009/12/07	0.00025	mg/L	No
2,4,6-Trichlorophenol	2009/12/07	0.001	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2009/12/07	0.00005	mg/L	No
Trifluralin	2009/12/07	0.00058	mg/L	No
Vinyl Chloride	2009/12/07	0.00025	mg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)