

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	260006490
Drinking-Water System	Levack Distribution System
Drinking-Water System Owner:	City of Greater Sudbury
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	From 2010-01-01 To 2010-03-09

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>www.greatersudbury.ca TDS-Engineering Department</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Number of Interested Authorities you report to: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes No

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library/Citizen Service Centre
- Public access/notice via other method _____

Describe your Drinking-Water System

The Levack Distribution system is no longer a standalone distribution system with a separate donor supply but has been combined with the Onaping Wells and Distribution system since November 2009. Due to a governmental disconnect, a separate Annual Report has to be completed for the period until the old Drinking Water System was end dated and therefore no longer recognized. End dating for the system was March 9, 2010. As such, this report includes all legislated requirements for the period January 1, 2010 until March 9, 2010.

List all water treatment chemicals used over this reporting period

Hydrofluosilicic Acid UN#1778

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to

Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
--	-------------------	--	---	-----------------------	--------------------------------------

Distribution					
	27	0 to 0	0 to 0	12	0 to 0

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #) - (max #)
Chlorine Residual Distribution System	8,760	1.17 - 1.98

NOTE: For continuous monitors use 8760 as the number of samples.

LEVACK FLUORIDE CHAMBER

Turbidity		
Chlorine		
Fluoride (If the DWS provides fluoridation)		

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent sample results

Drinking-Water Systems Regulation O. Reg. 170/03

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Lead				

LEVACK FLUORIDE CHAMBER

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2008/12/22	0.0005	mg/L	No
Arsenic	2008/12/22	0.001	mg/L	No
Barium	2008/12/22	0.0093	mg/L	No
Boron	2008/12/22	0.0095	mg/L	No
Cadmium	2008/12/22	0.0001	mg/L	No
Chromium	2008/12/22	0.001	mg/L	No
Mercury	2008/12/22	0.00018	mg/L	No
Selenium	2008/12/22	0.001	mg/L	No
Uranium	2008/12/22	0.001	mg/L	No
Nitrite				
Nitrate				
Sodium	2005/12/14	13.40	mg/L	No

Summary of lead testing under Schedule 15.1 during this reporting period.

Location Type	Number of Samples	Range of Lead Results (min#) - (max#)	Number of Exceedances
Plumbing		mg/L	
Distribution		mg/L	

Summary of Organic parameters sampled during this reporting period or most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)				

LEVACK FLUORIDE CHAMBER

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2008/12/22	0.0004	mg/L	No
Aldicarb	2008/12/22	0.00078	mg/L	No
Aldrin + Dieldrin	2008/12/22	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2008/12/22	0.0009	mg/L	No
Azinphos-methyl	2008/12/22	0.0003	mg/L	No
Bendiocarb	2008/12/22	0.0016	mg/L	No
Benzene	2008/12/22	0.00025	mg/L	No

Benzo(a)pyrene	2008/12/22	0.0000098	mg/L	No
Bromoxynil	2008/12/22	0.0005	mg/L	No
Carbaryl	2008/12/22	0.0016	mg/L	No
Carbofuran	2008/12/22	0.0016	mg/L	No
Carbon Tetrachloride	2008/12/22	0.00025	mg/L	No
Chlordane (Total)	2008/12/22	0.000004	mg/L	No
Chlorpyrifos	2008/12/22	0.0003	mg/L	No
Cyanazine	2008/12/22	0.0003	mg/L	No
Diazinon	2008/12/22	0.0003	mg/L	No
Dicamba	2008/12/22	0.0002	mg/L	No
1,2-Dichlorobenzene	2008/12/22	0.00025	mg/L	No
1,4-Dichlorobenzene	2008/12/22	0.00025	mg/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	2008/12/22	0.000005	mg/L	No
1,2-Dichloroethane	2008/12/22	0.00025	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2008/12/22	0.00025	mg/L	No
Dichloromethane	2008/12/22	0.00025	mg/L	No
2-4 Dichlorophenol	2008/12/22	0.000056	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2008/12/22	0.0002	mg/L	No
Diclofop-methyl	2008/12/22	0.0002	mg/L	No
Dimethoate	2008/12/22	0.0003	mg/L	No
Dinoseb	2008/12/22	0.00005	mg/L	No
Diquat	2008/12/22	0.007	mg/L	No
Diuron	2008/12/22	0.0078	mg/L	No
Glyphosate	2008/12/22	0.02	mg/L	No
Heptachlor + Heptachlor Epoxide	2008/12/22	0.000004	mg/L	No
Linadane (Total)	2008/12/22	0.00000027	mg/L	No
Malathion	2008/12/22	0.0003	mg/L	No
Methoxychlor	2008/12/22	0.00000072	mg/L	No
Metolachlor	2008/12/22	0.0002	mg/L	No
Metribuzin	2008/12/22	0.0002	mg/L	No
Monochlorobenzene	2008/12/22	0.00025	mg/L	No
Paraquat	2008/12/22	0.001	mg/L	No
Parathion	2008/12/22	0.0002	mg/L	No
Pentachlorophenol	2008/12/22	0.000056	mg/L	No
Phorate	2008/12/22	0.0003	mg/L	No
Picloram	2008/12/22	0.00005	mg/L	No
Polychlorinated Biphenyls(PCB)	2008/12/22	0.0000022	mg/L	No
Prometryne	2008/12/22	0.0002	mg/L	No
Simazine	2008/12/22	0.0003	mg/L	No
Temephos	2006/02/24	0.04	mg/L	No
Terbufos	2008/12/22	0.0002	mg/L	No
Tetrachloroethylene	2008/12/22	0.00025	mg/L	No
2,3,4,6-Tetrachlorophenol	2008/12/22	0.000056	mg/L	No
Triallate	2008/12/22	0.0002	mg/L	No
Trichloroethylene	2008/12/22	0.00025	mg/L	No
2,4,6-Trichlorophenol	2008/12/22	0.000056	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2008/12/22	0.00005	mg/L	No
Trifluralin	2008/12/22	0.0002	mg/L	No
Vinyl Chloride	2008/12/22	0.00025	mg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)