

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	24000020
Drinking-Water System	Nickel Rim
Drinking-Water System Owner:	City of Greater Sudbury
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	From 2010-01-01 To 2010-02-17

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>www.greatersudbury.ca TDS-Engineering Department</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Number of Interested Authorities you report to: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Falconbridge Distribution System	260006477

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes No

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library/Citizen Service Centre
- Public access/notice via other method _____

Describe your Drinking-Water System

The Nickel Rim Wells are no longer a standalone donor system with a separate distribution supply but have been purchased by the City of Greater Sudbury and combined into one drinking water system since April 2009. Due to a governmental disconnect, a separate Annual Report has to be completed for the period until the old Drinking Water System was end dated and therefore no longer recognized. End dating for the system was February 17, 2010. As such, this report includes all legislated requirements for the period January 1, 2010 until February 17, 2010.

List all water treatment chemicals used over this reporting period

Chlorine Gas UN#1017, Phosphate

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw: NICKEL RIM #5					
	7	0 to 0	0 to 0		
Raw: NICKEL RIM #6					
	7	0 to 0	0 to 0		
Raw: NICKEL RIM #7					
	7	0 to 0	0 to 0		
Treated: NICKEL RIM					
	9	0 to 0	0 to 0	9	0 to 10
Distribution					
	0	0 to 0	0 to 0	0	

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #) - (max #)
Chlorine Residual Distribution System		

***NOTE:** For continuous monitors use 8760 as the number of samples.*

NICKEL RIM

Turbidity	8,760	0.02 - 2.06	NTU
Chlorine	8,760	0.86 - 3.50	mg/L
Fluoride (If the DWS provides fluoridation)			

***NOTE:** Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Lead	2010/12/13	0.001	mg/L	No

NICKEL RIM

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Mercury				
Selenium				
Uranium				
Nitrite				
Nitrate				
Sodium				

Summary of lead testing under Schedule 15.1 during this reporting period.

Location Type	Number of Samples	Range of Lead Results (min#) - (max#)	Number of Exceedances
Plumbing		mg/L	
Distribution		mg/L	

Summary of Organic parameters sampled during this reporting period or most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)	2010	0.0010	mg/L	No

NICKEL RIM

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Linadane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
Temephos				

Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)