

**Part III Form 2**

**Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	210001111
<b>Drinking-Water System</b>	Wanapitei Water Treatment Plant and Distribution System
<b>Drinking-Water System Owner:</b>	City of Greater Sudbury
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	From 2009-01-01 To 2009-12-31

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>www.greatersudbury.ca TDS-Engineering Department</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Number of Interested Authorities you report to: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p>
--	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
Markstay-Warren	220013606
Garson Wells and Distribution System	220003485
David Street Water Treatment Plant	220003537

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes  No

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library/Citizen Service Centre
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

The City of Greater Sudbury includes the urban area of Sudbury and the surrounding outlying areas with the Wanapitei Water Treatment Plant servicing the northeastern and northwestern urban areas including Markstay, Coniston and parts of Garson (west of Falconbridge Road at O'Neil Drive) as well as supplying water to the Ellis Reservoir. The raw water is pumped from the Wanapitei River via the Wanapitei Intake which is situated just north of Hwy. 17 in the community of Wahnapiatae on the banks of the Wanapitei River. The Raw water is drawn from a concrete intake structure that protrudes approximately 18 metres into the Wanapitei River. The raw water passes through a coarse aluminum bar screen before it enters the Raw Water Intake Pumping Station then through two finer stainless steel screens inside the station before being pumped to the treatment plant approximately 2 km to the west. The Wanapitei Water Treatment utilizes a conventional water treatment process complete with Coagulation / Flocculation, Sedimentation and Filtration by dual media filters.

**List all water treatment chemicals used over this reporting period**

Chlorine Gas UN#1017, Hydrofluosilicic Acid UN#1778, Polyphosphate, Sodium Chlorite UN#1908, PAS-Aluminum Sulfate UN#3264, Hydrated Lime, Polyelectrolyte, Chlorine Dioxide (generated onsite)

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Engineering and Construction for UV upgrades and expansion: \$2,000,000.00  
 Intake security upgrades: \$30,000.00  
 Communications systems: \$34,000.00

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
2009/01/12	Turbidity	0.40	NTU	treated bacti sample	2009/01/16
2009/04/21	Pressure	0	psi	Resample/Re-test;	2009/04/24
2009/09/30	Pressure	<20	psi	Resampl/Re-test	2009/09/30
2009/11/05	Chlorine Residual	0.03	mg/L	Resample/Re-test	2009/09/09
2009/11/05	chlorine	<0.05	mg/l	Resample/Re-test;	2009/11/09

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
<b>Raw: WANAPITEI RIVER</b>					
	105	0 to 21	0 to 167		
<b>Treated: HL PUMP STATION, Sudbury (Wanapitei) WTP</b>					
	156	0 to 0	0 to 0	156	0 to 1500
<b>Distribution</b>					
	1,622	0 to 0	0 to 0	350	0 to 1540

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #) - (max #)
Chlorine Residual Distribution System	8,760	0.03 - 3.32 mg/L

*NOTE: For continuous monitors use 8760 as the number of samples.*

**HL PUMP STATION, Sudbury (Wanapitei) WTP**

Turbidity	8,760	0.00 - 2.43 NTU
Chlorine	8,760	1.00 - 3.41 mg/L
Fluoride (If the DWS provides fluoridation)	359	0.23 - 0.87 mg/L

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

**Summary of Inorganic parameters tested during this reporting period or most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Lead	2009/12/09	0.001	mg/L	No

**HL PUMP STATION, Sudburv (Wanapitei) WTP**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2009/12/07	0.0005	mg/L	No
Arsenic	2009/12/07	0.001	mg/L	No
Barium	2009/12/07	0.0156	mg/L	No
Boron	2009/12/07	0.0038	mg/L	No
Cadmium	2009/12/07	0.0001	mg/L	No
Chromium	2009/12/07	0.001	mg/L	No
Mercury	2009/12/07	0.00001	mg/L	No
Selenium	2009/12/07	0.001	mg/L	No
Uranium	2009/12/07	0.001	mg/L	No
Fluoride	2004/01/19	0.58	mg/L	No
Nitrate	2009/03/16	0.13	mg/L	No
	2009/06/15	0.11	mg/L	No
	2009/09/14	0.10	mg/L	No
	2009/12/14	0.13	mg/L	No
Nitrite	2009/03/16	0.05	mg/L	No
	2009/06/15	0.05	mg/L	No
	2009/09/14	0.05	mg/L	No
	2009/12/14	0.05	mg/L	No
Sodium	2005/12/14	1.60	mg/L	No

**Summary of lead testing under Schedule 15.1 during this reporting period.**

Location Type	Number of Samples	Range of Lead Results (min#) - (max#)	Number of Exceedances
Plumbing	176	0.001 - 0.002 mg/L	0
Distribution	34	0.001 - 0.001 mg/L	0

**Summary of Organic parameters sampled during this reporting period or most recent sample results**

**Drinking-Water Systems Regulation O. Reg. 170/03**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)	2009	0.0493	mg/L	No

**HL PUMP STATION, Sudbury (Wanapitei) WTP**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2009/12/07	0.00058	mg/L	No
Aldicarb	2009/12/07	0.00061	mg/L	No
Aldrin + Dieldrin	2009/12/07	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2009/12/07	0.0009	mg/L	No
Azinphos-methyl	2009/12/07	0.00035	mg/L	No
Bendiocarb	2009/12/07	0.0012	mg/L	No
Benzene	2009/12/07	0.00025	mg/L	No
Benzo(a)pyrene	2009/12/07	0.0000058	mg/L	No
Bromoxynil	2009/12/07	0.0005	mg/L	No
Carbaryl	2009/12/07	0.0012	mg/L	No
Carbofuran	2009/12/07	0.0012	mg/L	No
Carbon Tetrachloride	2009/12/07	0.00025	mg/L	No
Chlordane (Total)	2009/12/07	0.000004	mg/L	No
Chlorpyrifos	2009/12/07	0.00035	mg/L	No
Cyanazine	2009/12/07	0.00047	mg/L	No
Diazinon	2009/12/07	0.00035	mg/L	No
Dicamba	2009/12/07	0.0002	mg/L	No
1,2-Dichlorobenzene	2009/12/07	0.00025	mg/L	No
1,4-Dichlorobenzene	2009/12/07	0.00025	mg/L	No
(DDT) + metabolites	2009/12/07	0.000005	mg/L	No
1,2-Dichloroethane	2009/12/07	0.00025	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2009/12/07	0.00025	mg/L	No
Dichloromethane	2009/12/07	0.00025	mg/L	No
2-4 Dichlorophenol	2009/12/07	0.001	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2009/12/07	0.0002	mg/L	No
Diclofop-methyl	2009/12/07	0.0002	mg/L	No
Dimethoate	2009/12/07	0.00023	mg/L	No
Dinoseb	2009/12/07	0.00005	mg/L	No
Diquat	2009/12/07	0.007	mg/L	No
Diuron	2009/12/07	0.0061	mg/L	No
Glyphosate	2009/12/07	0.02	mg/L	No
Heptachlor + Heptachlor Epoxide	2009/12/07	0.000004	mg/L	No
Linadane (Total)	2009/12/07	0.00000034	mg/L	No
Malathion	2009/12/07	0.00023	mg/L	No
Methoxychlor	2009/12/07	0.00000091	mg/L	No
Metolachlor	2009/12/07	0.00023	mg/L	No
Metribuzin	2009/12/07	0.00023	mg/L	No
Monochlorobenzene	2009/12/07	0.00025	mg/L	No
Paraquat	2009/12/07	0.001	mg/L	No
Parathion	2009/12/07	0.00035	mg/L	No
Pentachlorophenol	2009/12/07	0.001	mg/L	No
Phorate	2009/12/07	0.00035	mg/L	No
Picloram	2009/12/07	0.00005	mg/L	No
Polychlorinated Biphenyls(PCB)	2009/12/07	0.0000032	mg/L	No
Prometryne	2009/12/07	0.00023	mg/L	No

## Drinking-Water Systems Regulation O. Reg. 170/03

Simazine	2009/12/07	0.00058	mg/L	No
Temephos	2009/12/07	0.017	mg/L	No
Terbufos	2009/12/07	0.00035	mg/L	No
Tetrachloroethylene	2009/12/07	0.00025	mg/L	No
2,3,4,6-Tetrachlorophenol	2009/12/07	0.001	mg/L	No
Triallate	2009/12/07	0.00058	mg/L	No
Trichloroethylene	2009/12/07	0.00025	mg/L	No
2,4,6-Trichlorophenol	2009/12/07	0.001	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2009/12/07	0.00005	mg/L	No
Trifluralin	2009/12/07	0.00058	mg/L	No
Vinyl Chloride	2009/12/07	0.00025	mg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)**