

**Part III Form 2**  
**Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	210000737
<b>Drinking-Water System</b>	Valley Wells and Distribution System
<b>Drinking-Water System Owner:</b>	City of Greater Sudbury
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	From 2007-01-01 To 2007-12-31

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>www.greatersudbury.ca          TDS-Engineering Department</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Number of Interested Authorities you report to: <input type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p>
---	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
Capreol Wells and Distribution System	220003528

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes  No

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web**
- Public access/notice via Government Office**
- Public access/notice via a newspaper**
- Public access/notice via Public Request**
- Public access/notice via a Public Library/Citizen Service Centre**
- Public access/notice via other method**

**Describe your Drinking-Water System**

The Valley East Distribution encompasses the communities of Chelmsford, Azilda, McCrea Heights, Blezard Valley, Val Caron, Val Therese and Hanmer The Valley East System includes nine wells in a well field that extends approximately 7.5 km (west to east) from Val Therese to Hanmer and three storage tanks that are situated in Azilda, Chelmsford and Val Caron. The wells are designated (derived from the street location) as Kenneth, Philippe, Deschene, Frost, Notre Dame, Michelle, Linden, Pharand and I Well ( except I Well which is located on Regional Road 84). The wells take water from a relatively shallow unconfined aquifer situated in a predominantly sand to sand / gravel formation. The discharge from each well undergoes treatment in the form of disinfection by chlorination, Ultra-Violet irradiation, and fluoridation before it enters the distribution water mains. All of the Valley Wells wells were upgraded, in 2007, to include Ultra-Violet irradiation as required for Log removal regulations. In the event of high water demands or failure from the Capreol Well and booster system, Capreol will be supplied with water from the Valley Wells but at a reduced pressure.

**List all water treatment chemicals used over this reporting period**

Chlorine Gas UN#1017, Hydrofluosilicic Acid (20-30%) UN#1778,

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Rehab of and additional work at Linden well "F", partial replacement of column pipe and install new well liner at a cost of approximately \$60,000.  
 Installation of 9 UV units at all well sites at a cost of approximately \$1,000,000.  
 Inspection, clean and report on Chelmsford elevated water storage tank at a cost of approximately \$10,000.

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
2007/06/10	UV	38.8 - 39.9	mj/cm <sup>2</sup>	Disinfectant restored/increased;	2007/06/10
2007/06/11	UV	33.3	mj/cm <sup>2</sup>	Disinfectant restored/increased;	2007/06/11
2007/06/11	UV	32	mj/cm <sup>2</sup>	Disinfectant restored/increased;	2007/06/11
2007/10/21	Pressure / UV	0/1.67	psi / mj/cm <sup>2</sup>	Resample/Re-test;	2007/10/21
2007/11/20	UV	0	mj/cm <sup>2</sup>	Disinfectant restored/increased;	2007/12/12
2007/11/23	UV	0	mj/cm <sup>2</sup>	Disinfectant restored/increased;	2007/11/26
2007/12/04	UV	0	mj/cm <sup>2</sup>	Disinfectant restored/increased;	2007/12/04
2007/12/26	UV	0	mj/cm <sup>2</sup>	Resample/Re-test;	2007/12/28

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
<b>Raw: KENNETH WELL</b>					
	51	0 to 0	0 to 0		
<b>Raw: DESCHENE WELL</b>					
	52	0 to 0	0 to 0		
<b>Raw: FROST WELL</b>					
	53	0 to 0	0 to 0		
<b>Raw: MICHELLE WELL</b>					
	52	0 to 0	0 to 0		
<b>Raw: NOTRE DAME WELL</b>					
	52	0 to 0	0 to 0		
<b>Raw: LINDEN WELL</b>					
	50	0 to 0	0 to 4		
<b>Raw: PHARAND WELL</b>					
	51	0 to 0	0 to 2		
<b>Raw: I WELL</b>					
	51	0 to 0	0 to 0		
<b>Raw: PHILIPPE WELL</b>					
	53	0 to 0	0 to 0		

<b>Treated: WELL A - DESCHENE WELL</b>					
	53	0 to 0	0 to 0	52	0 to 40
<b>Treated: WELL B - KENNETH WELL</b>					
	52	0 to 0	0 to 0	50	0 to 70
<b>Treated: WELL C - PHILIPPE WELL</b>					
	54	0 to 0	0 to 0	52	0 to 10
<b>Treated: WELL D - FROST WELL</b>					
	54	0 to 0	0 to 0	52	0 to 10
<b>Treated: WELL E - NOTRE DAME WELL</b>					
	53	0 to 0	0 to 0	51	0 to 90
<b>Treated: WELL F - LINDEN WELL</b>					
	51	0 to 0	0 to 0	49	0 to 10
<b>Treated: WELL G - PHARAND WELL</b>					
	51	0 to 0	0 to 0	49	0 to 10
<b>Treated: WELL H - MICHELLE WELL</b>					
	53	0 to 0	0 to 0	52	0 to 10
<b>Treated: WELL I - I WELL</b>					
	52	0 to 0	0 to 0	50	0 to 140
<b>Distribution</b>					
	659	0 to 0	0 to 0	166	0 to 60

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	<b>Number of Grab Samples</b>	<b>Range of Results (min #) - (max #)</b>
<b>Chlorine Residual Distribution System</b>	8,760	0.34 - 1.99

*NOTE: For continuous monitors use 8760 as the number of samples.*

**WELL A - DESCHENE WELL**

<b>Turbidity</b>	8,760	0.00 - 2.00
<b>Chlorine</b>	8,760	0.56 - 2.00
<b>Fluoride (If the DWS provides fluoridation)</b>	8,760	0.20 - 0.97

**WELL B - KENNETH WELL**

<b>Turbidity</b>	8,760	0.00 - 2.00
<b>Chlorine</b>	8,760	0.05 - 2.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.20 - 0.95

**WELL C - PHILIPPE WELL**

<b>Turbidity</b>	8,760	0.00 - 1.03
<b>Chlorine</b>	8,760	0.12 - 2.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.20 - 1.03

**WELL D - FROST WELL**

<b>Turbidity</b>	8,760	0.00 - 0.98
<b>Chlorine</b>	8,760	0.15 - 2.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.20 - 0.99

**WELL E - NOTRE DAME WELL**

<b>Turbidity</b>	8,760	0.00 - 1.54
<b>Chlorine</b>	8,760	0.06 - 2.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.20 - 1.07

**WELL F - LINDEN WELL**

<b>Turbidity</b>	8,760	0.04 - 2.00
<b>Chlorine</b>	8,760	0.25 - 3.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.20 - 1.19

**WELL G - PHARAND WELL**

<b>Turbidity</b>	8,760	0.00 - 2.00
<b>Chlorine</b>	8,760	0.05 - 2.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.20 - 1.15

**WELL H - MICHELLE WELL**

<b>Turbidity</b>	8,760	0.00 - 2.00
<b>Chlorine</b>	8,760	0.05 - 2.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.20 - 1.15

**WELL I - I WELL**

<b>Turbidity</b>	8,760	0.01 - 2.00
<b>Chlorine</b>	8,760	0.35 - 2.00
<b>Fluoride</b> (If the DWS provides fluoridation)	8,760	0.00 - 1.47

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

**Summary of Inorganic parameters tested during this reporting period or most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Lead	2007/03/07	<0.001	mg/L	No

**WELL A - DESCHENE WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2007/03/07	0.0005	mg/L	No
Arsenic	2007/03/07	0.0014	mg/L	No
Barium	2007/03/07	0.0104	mg/L	No
Boron	2007/03/07	0.01	mg/L	No
Cadmium	2007/03/07	0.0001	mg/L	No
Chromium	2007/03/07	0.0034	mg/L	No
Mercury	2007/03/07	0.0001	mg/L	No
Selenium	2007/03/07	0.001	mg/L	No
Uranium	2007/03/07	0.001	mg/L	No
Fluoride	2004/01/22	0.49	mg/L	No
Nitrate	2007/01/29	1.08	mg/L	No
	2007/04/12	1.03	mg/L	No
	2007/06/19	0.90	mg/L	No
	2007/08/27	0.88	mg/L	No
	2007/09/25	0.97	mg/L	No
	2007/11/05	0.85	mg/L	No
Nitrite	2007/01/29	0.05	mg/L	No
	2007/04/12	0.05	mg/L	No
	2007/06/19	0.05	mg/L	No
	2007/08/27	0.05	mg/L	No
	2007/09/25	0.03	mg/L	No
	2007/11/05	0.05	mg/L	No
Sodium	2006/01/04	8.98	mg/L	No

**WELL B - KENNETH WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2007/03/07	0.0005	mg/L	No
Arsenic	2007/03/07	0.001	mg/L	No
Barium	2007/03/07	0.041	mg/L	No
Boron	2007/03/07	0.016	mg/L	No
Cadmium	2007/03/07	0.0001	mg/L	No
Chromium	2007/03/07	0.006	mg/L	No
Mercury	2007/03/07	0.00012	mg/L	No
Selenium	2007/03/07	0.001	mg/L	No
Uranium	2007/03/07	0.001	mg/L	No
Fluoride	2004/01/21	0.1	mg/L	No
Nitrate	2007/01/30	0.42	mg/L	No
	2007/04/10	0.32	mg/L	No
	2007/06/19	0.30	mg/L	No
	2007/08/28	0.28	mg/L	No
	2007/09/24	0.24	mg/L	No
	2007/11/05	0.31	mg/L	No
Nitrite	2007/01/30	0.05	mg/L	No
	2007/04/10	0.05	mg/L	No
	2007/06/19	0.05	mg/L	No
	2007/08/28	0.05	mg/L	No
	2007/09/24	0.03	mg/L	No
	2007/11/05	0.05	mg/L	No
Sodium	2005/12/23	14.00	mg/L	No

**WELL C - PHILIPPE WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2007/03/07	0.0005	mg/L	No
Arsenic	2007/03/07	0.0015	mg/L	No
Barium	2007/03/07	0.008	mg/L	No
Boron	2007/03/07	0.0045	mg/L	No
Cadmium	2007/03/07	0.0002	mg/L	No
Chromium	2007/03/07	0.0026	mg/L	No
Mercury	2007/03/07	0.0001	mg/L	No
Selenium	2007/03/07	0.001	mg/L	No
Uranium	2007/03/07	0.001	mg/L	No
Fluoride	2004/01/21	0.58	mg/L	No
Nitrate	2007/01/29	0.30	mg/L	No
	2007/04/10	0.21	mg/L	No
	2007/06/19	0.15	mg/L	No
	2007/08/27	0.24	mg/L	No
	2007/09/25	0.23	mg/L	No
	2007/11/05	0.22	mg/L	No

**Drinking-Water Systems Regulation O. Reg. 170/03**

<b>Nitrite</b>	2007/01/29	0.05	mg/L	No
	2007/04/10	0.05	mg/L	No
	2007/06/19	0.05	mg/L	No
	2007/08/27	0.05	mg/L	No
	2007/09/25	0.03	mg/L	No
	2007/11/05	0.05	mg/L	No
<b>Sodium</b>	2005/12/14	19.40	mg/L	No

**WELL D - FROST WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	2007/03/07	0.0005	mg/L	No
<b>Arsenic</b>	2007/03/07	0.0018	mg/L	No
<b>Barium</b>	2007/03/07	0.0283	mg/L	No
<b>Boron</b>	2007/03/07	0.0083	mg/L	No
<b>Cadmium</b>	2007/03/07	0.0001	mg/L	No
<b>Chromium</b>	2007/03/07	0.0034	mg/L	No
<b>Mercury</b>	2007/03/07	0.0001	mg/L	No
<b>Selenium</b>	2007/03/07	0.001	mg/L	No
<b>Uranium</b>	2007/03/07	0.001	mg/L	No
<b>Fluoride</b>	2004/01/21	0.37	mg/L	No
<b>Nitrate</b>	2007/01/30	0.10	mg/L	No
	2007/04/11	0.49	mg/L	No
	2007/06/20	0.42	mg/L	No
	2007/08/27	0.47	mg/L	No
	2007/09/26	0.47	mg/L	No
	2007/11/07	0.50	mg/L	No
<b>Nitrite</b>	2007/01/30	0.05	mg/L	No
	2007/04/11	0.05	mg/L	No
	2007/06/20	0.05	mg/L	No
	2007/08/27	0.05	mg/L	No
	2007/09/26	0.03	mg/L	No
	2007/11/07	0.05	mg/L	No
<b>Sodium</b>	2005/12/14	16.90	mg/L	No

**WELL E - NOTRE DAME WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	2007/03/07	0.0005	mg/L	No
<b>Arsenic</b>	2007/03/07	0.001	mg/L	No
<b>Barium</b>	2007/03/07	0.0143	mg/L	No
<b>Boron</b>	2007/03/07	0.0074	mg/L	No
<b>Cadmium</b>	2007/03/07	0.00017	mg/L	No
<b>Chromium</b>	2007/03/07	0.0017	mg/L	No
<b>Mercury</b>	2007/03/07	0.0001	mg/L	No
<b>Selenium</b>	2007/03/07	0.001	mg/L	No
<b>Uranium</b>	2007/03/07	0.001	mg/L	No
<b>Fluoride</b>	2004/01/22	0.61	mg/L	No

**Drinking-Water Systems Regulation O. Reg. 170/03**

<b>Nitrate</b>	2007/01/29	0.85	mg/L	No
	2007/04/11	0.79	mg/L	No
	2007/06/19	0.67	mg/L	No
	2007/08/28	0.71	mg/L	No
	2007/09/25	0.73	mg/L	No
	2007/11/08	0.68	mg/L	No
<b>Nitrite</b>	2007/01/29	0.05	mg/L	No
	2007/04/11	0.05	mg/L	No
	2007/06/19	0.05	mg/L	No
	2007/08/28	0.05	mg/L	No
	2007/09/25	0.03	mg/L	No
	2007/11/08	0.05	mg/L	No
<b>Sodium</b>	2005/12/28	8.98	mg/L	No

**WELL F - LINDEN WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	2007/03/07	0.0005	mg/L	No
<b>Arsenic</b>	2007/03/07	0.0021	mg/L	No
<b>Barium</b>	2007/03/07	0.0172	mg/L	No
<b>Boron</b>	2007/03/07	0.0046	mg/L	No
<b>Cadmium</b>	2007/03/07	0.00031	mg/L	No
<b>Chromium</b>	2007/03/07	0.001	mg/L	No
<b>Mercury</b>	2007/03/07	0.0001	mg/L	No
<b>Selenium</b>	2007/03/07	0.001	mg/L	No
<b>Uranium</b>	2007/03/07	0.001	mg/L	No
<b>Fluoride</b>	2004/01/22	0.71	mg/L	No
<b>Nitrate</b>	2007/01/29	0.27	mg/L	No
	2007/04/11	0.22	mg/L	No
	2007/06/19	0.13	mg/L	No
	2007/08/28	0.18	mg/L	No
	2007/11/09	0.24	mg/L	No
<b>Nitrite</b>	2007/01/29	0.05	mg/L	No
	2007/04/11	0.09	mg/L	No
	2007/06/19	0.05	mg/L	No
	2007/08/28	0.05	mg/L	No
	2007/11/09	0.05	mg/L	No
<b>Sodium</b>	2005/12/14	11.60	mg/L	No

**WELL G - PHARAND WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2007/03/07	0.0005	mg/L	No
Arsenic	2007/03/07	0.0011	mg/L	No
Barium	2007/03/07	0.0344	mg/L	No
Boron	2007/03/07	0.017	mg/L	No
Cadmium	2007/03/07	0.00074	mg/L	No
Chromium	2007/03/07	0.0034	mg/L	No
Mercury	2007/03/07	0.0001	mg/L	No
Selenium	2007/03/07	0.001	mg/L	No
Uranium	2007/03/07	0.001	mg/L	No
Fluoride	2004/01/22	0.1	mg/L	No
Nitrate	2007/01/30	2.10	mg/L	No
	2007/04/12	1.90	mg/L	No
	2007/06/20	1.73	mg/L	No
	2007/08/28	1.75	mg/L	No
	2007/09/25	1.85	mg/L	No
	2007/11/07	1.76	mg/L	No
Nitrite	2007/01/30	0.05	mg/L	No
	2007/04/12	0.05	mg/L	No
	2007/06/20	0.05	mg/L	No
	2007/08/28	0.05	mg/L	No
	2007/09/25	0.03	mg/L	No
	2007/11/07	0.05	mg/L	No
Sodium	2005/12/23	75.10	mg/L	Yes

**WELL H - MICHELLE WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2007/03/07	0.0005	mg/L	No
Arsenic	2007/03/07	0.0012	mg/L	No
Barium	2007/03/07	0.0153	mg/L	No
Boron	2007/03/07	0.0078	mg/L	No
Cadmium	2007/03/07	0.0001	mg/L	No
Chromium	2007/03/07	0.0026	mg/L	No
Mercury	2007/03/07	0.0001	mg/L	No
Selenium	2007/03/07	0.001	mg/L	No
Uranium	2007/03/07	0.001	mg/L	No
Fluoride	2004/01/21	0.17	mg/L	No
Nitrate	2007/01/29	1.12	mg/L	No
	2007/04/12	1.36	mg/L	No
	2007/06/19	0.92	mg/L	No
	2007/08/27	0.96	mg/L	No
	2007/09/25	1.01	mg/L	No
	2007/11/07	0.96	mg/L	No

<b>Nitrite</b>	2007/01/29	0.05	mg/L	No
	2007/04/12	0.05	mg/L	No
	2007/06/19	0.05	mg/L	No
	2007/08/27	0.05	mg/L	No
	2007/09/25	0.03	mg/L	No
	2007/11/07	0.05	mg/L	No
<b>Sodium</b>	2005/12/14	36.00	mg/L	Yes

**WELL I - I WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	2007/03/07	0.0005	mg/L	No
<b>Arsenic</b>	2007/03/07	0.001	mg/L	No
<b>Barium</b>	2007/03/07	0.0127	mg/L	No
<b>Boron</b>	2007/03/07	0.004	mg/L	No
<b>Cadmium</b>	2007/03/07	0.00333	mg/L	No
<b>Chromium</b>	2007/03/07	0.0015	mg/L	No
<b>Mercury</b>	2007/03/07	0.0001	mg/L	No
<b>Selenium</b>	2007/03/07	0.001	mg/L	No
<b>Uranium</b>	2007/03/07	0.001	mg/L	No
<b>Fluoride</b>	2004/01/22	0.1	mg/L	No
<b>Nitrate</b>	2007/01/30	0.59	mg/L	No
	2007/04/12	0.10	mg/L	No
	2007/06/19	0.10	mg/L	No
	2007/08/29	0.10	mg/L	No
	2007/11/08	0.10	mg/L	No
<b>Nitrite</b>	2007/01/30	0.05	mg/L	No
	2007/04/12	0.05	mg/L	No
	2007/06/19	0.05	mg/L	No
	2007/08/29	0.05	mg/L	No
	2007/11/08	0.05	mg/L	No
<b>Sodium</b>	2005/12/14	2.00	mg/L	No

**Summary of Organic parameters sampled during this reporting period or most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>THM</b> (NOTE: show latest annual average)	2007	0.0098	mg/L	No

**WELL A - DESCHENE WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Alachlor</b>	2006/02/23	0.001	mg/L	No
<b>Aldicarb</b>	2006/02/23	0.001	mg/L	No
<b>Aldrin + Dieldrin</b>	2006/02/23	0.000004	mg/L	No
<b>Atrazine + N-dealkylated metabolites</b>	2006/02/23	0.0009	mg/L	No
<b>Azinphos-methyl</b>	2006/02/23	0.001	mg/L	No
<b>Bendiocarb</b>	2006/02/23	0.002	mg/L	No

Benzene	2006/02/23	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/23	0.00001	mg/L	No
Bromoxynil	2006/02/23	0.001	mg/L	No
Carbaryl	2006/02/23	0.002	mg/L	No
Carbofuran	2006/02/23	0.002	mg/L	No
Carbon Tetrachloride	2006/02/23	0.0003	mg/L	No
Chlordane (Total)	2006/02/23	0.000004	mg/L	No
Chlorpyrifos	2006/02/23	0.001	mg/L	No
Cyanazine	2006/02/23	0.001	mg/L	No
Diazinon	2006/02/23	0.001	mg/L	No
Dicamba	2006/02/23	0.0004	mg/L	No
1,2-Dichlorobenzene	2006/02/23	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/23	0.0003	mg/L	No
(DDT) + metabolites	2006/02/23	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/23	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/23	0.0003	mg/L	No
Dichloromethane	2006/02/23	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/23	0.001	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/23	0.0004	mg/L	No
Diclofop-methyl	2006/02/23	0.0004	mg/L	No
Dimethoate	2006/02/23	0.001	mg/L	No
Dinoseb	2006/02/23	0.0001	mg/L	No
Diquat	2006/02/23	0.007	mg/L	No
Diuron	2006/02/23	0.001	mg/L	No
Glyphosate	2006/02/23	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/02/23	0.000004	mg/L	No
Linadane (Total)	2006/02/23	0.000001	mg/L	No
Malathion	2006/02/23	0.001	mg/L	No
Methoxychlor	2006/02/23	0.000004	mg/L	No
Metolachlor	2006/02/23	0.0007	mg/L	No
Metribuzin	2006/02/23	0.0007	mg/L	No
Monochlorobenzene	2006/02/23	0.0003	mg/L	No
Paraquat	2006/02/23	0.001	mg/L	No
Parathion	2006/02/23	0.0007	mg/L	No
Pentachlorophenol	2006/02/23	0.001	mg/L	No
Phorate	2006/02/23	0.001	mg/L	No
Picloram	2006/02/23	0.0001	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/23	0.0002	mg/L	No
Prometryne	2006/02/23	0.0007	mg/L	No
Simazine	2006/02/23	0.001	mg/L	No
Temephos	2006/02/23	0.03	mg/L	No
Terbufos	2006/02/23	0.0007	mg/L	No
Tetrachloroethylene	2006/02/23	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/02/23	0.001	mg/L	No
Triallate	2006/02/23	0.0007	mg/L	No
Trichloroethylene	2006/02/23	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/23	0.001	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/23	0.0001	mg/L	No
Trifluralin	2006/02/23	0.0007	mg/L	No
Vinyl Chloride	2006/02/23	0.0003	mg/L	No

**WELL B - KENNETH WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/02/23	0.0008	mg/L	No
Aldicarb	2006/02/23	0.0009	mg/L	No
Aldrin + Dieldrin	2006/02/23	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/02/23	0.0009	mg/L	No
Azinphos-methyl	2006/02/23	0.0006	mg/L	No
Bendiocarb	2006/02/23	0.002	mg/L	No
Benzene	2006/02/23	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/23	0.00001	mg/L	No
Bromoxynil	2006/02/23	0.0008	mg/L	No
Carbaryl	2006/02/23	0.002	mg/L	No
Carbofuran	2006/02/23	0.002	mg/L	No
Carbon Tetrachloride	2006/02/23	0.0003	mg/L	No
Chlordane (Total)	2006/02/23	0.000004	mg/L	No
Chlorpyrifos	2006/02/23	0.0006	mg/L	No
Cyanazine	2006/02/23	0.0006	mg/L	No
Diazinon	2006/02/23	0.0006	mg/L	No
Dicamba	2006/02/23	0.0003	mg/L	No
1,2-Dichlorobenzene	2006/02/23	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/23	0.0003	mg/L	No
(DDT) + metabolites	2006/02/23	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/23	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/23	0.0003	mg/L	No
Dichloromethane	2006/02/23	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/23	0.001	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/23	0.0003	mg/L	No
Diclofop-methyl	2006/02/23	0.0003	mg/L	No
Dimethoate	2006/02/23	0.0006	mg/L	No
Dinoseb	2006/02/23	0.00008	mg/L	No
Diquat	2006/02/23	0.007	mg/L	No
Diuron	2006/02/23	0.0009	mg/L	No
Glyphosate	2006/02/23	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/02/23	0.000004	mg/L	No
Linadane (Total)	2006/02/23	0.000002	mg/L	No
Malathion	2006/02/23	0.0006	mg/L	No
Methoxychlor	2006/02/23	0.000005	mg/L	No
Metolachlor	2006/02/23	0.0004	mg/L	No
Metribuzin	2006/02/23	0.0004	mg/L	No
Monochlorobenzene	2006/02/23	0.0003	mg/L	No
Paraquat	2006/02/23	0.001	mg/L	No
Parathion	2006/02/23	0.0004	mg/L	No
Pentachlorophenol	2006/02/23	0.001	mg/L	No
Phorate	2006/02/23	0.0006	mg/L	No
Picloram	2006/02/23	0.00008	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/23	0.0003	mg/L	No
Prometryne	2006/02/23	0.0004	mg/L	No
Simazine	2006/02/23	0.0006	mg/L	No
Temephos	2006/02/23	0.03	mg/L	No
Terbufos	2006/02/23	0.0004	mg/L	No
Tetrachloroethylene	2006/02/23	0.0003	mg/L	No

2,3,4,6-Tetrachlorophenol	2006/02/23	0.001	mg/L	No
Triallate	2006/02/23	0.0004	mg/L	No
Trichloroethylene	2006/02/23	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/23	0.001	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/23	0.00008	mg/L	No
Trifluralin	2006/02/23	0.0004	mg/L	No
Vinyl Chloride	2006/02/23	0.0003	mg/L	No

**WELL C - PHILIPPE WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/02/23	0.002	mg/L	No
Aldicarb	2006/02/23	0.001	mg/L	No
Aldrin + Dieldrin	2006/02/23	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/02/23	0.0009	mg/L	No
Azinphos-methyl	2006/02/23	0.002	mg/L	No
Bendiocarb	2006/02/23	0.002	mg/L	No
Benzene	2006/02/23	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/23	0.00001	mg/L	No
Bromoxynil	2006/02/23	0.0007	mg/L	No
Carbaryl	2006/02/23	0.002	mg/L	No
Carbofuran	2006/02/23	0.002	mg/L	No
Carbon Tetrachloride	2006/02/23	0.0003	mg/L	No
Chlordane (Total)	2006/02/23	0.000004	mg/L	No
Chlorpyrifos	2006/02/23	0.002	mg/L	No
Cyanazine	2006/02/23	0.002	mg/L	No
Diazinon	2006/02/23	0.002	mg/L	No
Dicamba	2006/02/23	0.0003	mg/L	No
1,2-Dichlorobenzene	2006/02/23	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/23	0.0003	mg/L	No
(DDT) + metabolites	2006/02/23	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/23	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/23	0.0003	mg/L	No
Dichloromethane	2006/02/23	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/23	0.002	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/23	0.0003	mg/L	No
Diclofop-methyl	2006/02/23	0.0003	mg/L	No
Dimethoate	2006/02/23	0.002	mg/L	No
Dinoseb	2006/02/23	0.00007	mg/L	No
Diquat	2006/02/23	0.007	mg/L	No
Diuron	2006/02/23	0.001	mg/L	No
Glyphosate	2006/02/23	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/02/23	0.000004	mg/L	No
Linadane (Total)	2006/02/23	0.000002	mg/L	No
Malathion	2006/02/23	0.002	mg/L	No
Methoxychlor	2006/02/23	0.000005	mg/L	No
Metolachlor	2006/02/23	0.001	mg/L	No
Metribuzin	2006/02/23	0.001	mg/L	No
Monochlorobenzene	2006/02/23	0.0003	mg/L	No
Paraquat	2006/02/23	0.001	mg/L	No
Parathion	2006/02/23	0.001	mg/L	No

Pentachlorophenol	2006/02/23	0.002	mg/L	No
Phorate	2006/02/23	0.002	mg/L	No
Picloram	2006/02/23	0.00007	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/23	0.0003	mg/L	No
Prometryne	2006/02/23	0.001	mg/L	No
Simazine	2006/02/23	0.002	mg/L	No
Temephos	2006/02/23	0.03	mg/L	No
Terbufos	2006/02/23	0.001	mg/L	No
Tetrachloroethylene	2006/02/23	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/02/23	0.002	mg/L	No
Triallate	2006/02/23	0.001	mg/L	No
Trichloroethylene	2006/02/23	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/23	0.002	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/23	0.00007	mg/L	No
Trifluralin	2006/02/23	0.001	mg/L	No
Vinyl Chloride	2006/02/23	0.0003	mg/L	No

**WELL D - FROST WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/02/22	0.0005	mg/L	No
Aldicarb	2006/02/22	0.0009	mg/L	No
Aldrin + Dieldrin	2006/02/22	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/02/22	0.0009	mg/L	No
Azinphos-methyl	2006/02/22	0.0004	mg/L	No
Bendiocarb	2006/02/22	0.002	mg/L	No
Benzene	2006/02/22	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/22	0.00001	mg/L	No
Bromoxynil	2006/02/22	0.0005	mg/L	No
Carbaryl	2006/02/22	0.002	mg/L	No
Carbofuran	2006/02/22	0.002	mg/L	No
Carbon Tetrachloride	2006/02/22	0.0003	mg/L	No
Chlordane (Total)	2006/02/22	0.000004	mg/L	No
Chlorpyrifos	2006/02/22	0.0004	mg/L	No
Cyanazine	2006/02/22	0.0004	mg/L	No
Diazinon	2006/02/22	0.0004	mg/L	No
Dicamba	2006/02/22	0.0002	mg/L	No
1,2-Dichlorobenzene	2006/02/22	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/22	0.0003	mg/L	No
(DDT) + metabolites	2006/02/22	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/22	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/22	0.0003	mg/L	No
Dichloromethane	2006/02/22	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/22	0.002	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/22	0.0002	mg/L	No
Diclofop-methyl	2006/02/22	0.0002	mg/L	No
Dimethoate	2006/02/22	0.0004	mg/L	No
Dinoseb	2006/02/22	0.00005	mg/L	No
Diquat	2006/02/22	0.007	mg/L	No
Diuron	2006/02/22	0.0009	mg/L	No
Glyphosate	2006/02/22	0.01	mg/L	No

Heptachlor + Heptachlor Epoxide	2006/02/22	0.000004	mg/L	No
Linadane (Total)	2006/02/22	0.000001	mg/L	No
Malathion	2006/02/22	0.0004	mg/L	No
Methoxychlor	2006/02/22	0.000003	mg/L	No
Metolachlor	2006/02/22	0.0003	mg/L	No
Metribuzin	2006/02/22	0.0003	mg/L	No
Monochlorobenzene	2006/02/22	0.0003	mg/L	No
Paraquat	2006/02/22	0.001	mg/L	No
Parathion	2006/02/22	0.0003	mg/L	No
Pentachlorophenol	2006/02/22	0.002	mg/L	No
Phorate	2006/02/22	0.0004	mg/L	No
Picloram	2006/02/22	0.00005	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/22	0.0002	mg/L	No
Prometryne	2006/02/22	0.0003	mg/L	No
Simazine	2006/02/22	0.0004	mg/L	No
Temephos	2006/02/22	0.02	mg/L	No
Terbufos	2006/02/22	0.0003	mg/L	No
Tetrachloroethylene	2006/02/22	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/02/22	0.002	mg/L	No
Triallate	2006/02/22	0.0003	mg/L	No
Trichloroethylene	2006/02/22	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/22	0.002	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/22	0.00005	mg/L	No
Trifluralin	2006/02/22	0.0003	mg/L	No
Vinyl Chloride	2006/02/22	0.0003	mg/L	No

**WELL E - NOTRE DAME WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/05/04	0.0005	mg/L	No
Aldicarb	2006/05/04	0.005	mg/L	No
Aldrin + Dieldrin	2006/05/04	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/05/04	0.001	mg/L	No
Azinphos-methyl	2006/05/04	0.002	mg/L	No
Bendiocarb	2006/05/04	0.002	mg/L	No
Benzene	2006/05/05	0.0003	mg/L	No
Benzo(a)pyrene	2006/05/04	0.000009	mg/L	No
Bromoxynil	2006/05/04	0.0008	mg/L	No
Carbaryl	2006/05/04	0.005	mg/L	No
Carbofuran	2006/05/04	0.005	mg/L	No
Carbon Tetrachloride	2006/05/05	0.0003	mg/L	No
Chlordane (Total)	2006/05/04	0.000004	mg/L	No
Chlorpyrifos	2006/05/04	0.001	mg/L	No
Cyanazine	2006/05/04	0.001	mg/L	No
Diazinon	2006/05/04	0.001	mg/L	No
Dicamba	2006/05/04	0.001	mg/L	No
1,2-Dichlorobenzene	2006/05/05	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/05/05	0.0003	mg/L	No
(DDT) + metabolites	2006/05/04	0.000005	mg/L	No
1,2-Dichloroethane	2006/05/05	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/05/05	0.0003	mg/L	No

Dichloromethane	2006/05/05	0.0003	mg/L	No
2-4 Dichlorophenol	2006/05/04	0.0001	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/05/04	0.001	mg/L	No
Diclofop-methyl	2006/05/04	0.0009	mg/L	No
Dimethoate	2006/05/04	0.003	mg/L	No
Dinoseb	2006/05/04	0.001	mg/L	No
Diquat	2006/05/04	0.007	mg/L	No
Diuron	2006/05/04	0.01	mg/L	No
Glyphosate	2006/05/04	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/05/04	0.000004	mg/L	No
Linadane (Total)	2006/05/04	0.000006	mg/L	No
Malathion	2006/05/04	0.005	mg/L	No
Methoxychlor	2006/05/04	0.000008	mg/L	No
Metolachlor	2006/05/04	0.0005	mg/L	No
Metribuzin	2006/05/04	0.005	mg/L	No
Monochlorobenzene	2006/05/05	0.0003	mg/L	No
Paraquat	2006/05/04	0.001	mg/L	No
Parathion	2006/05/04	0.001	mg/L	No
Pentachlorophenol	2006/05/04	0.0005	mg/L	No
Phorate	2006/05/04	0.0005	mg/L	No
Picloram	2006/05/04	0.005	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/05/04	0.0002	mg/L	No
Prometryne	2006/05/04	0.0003	mg/L	No
Simazine	2006/05/04	0.001	mg/L	No
Temephos	2006/05/04	0.01	mg/L	No
Terbufos	2006/05/04	0.0007	mg/L	No
Tetrachloroethylene	2006/05/05	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/05/04	0.0001	mg/L	No
Triallate	2006/05/04	0.001	mg/L	No
Trichloroethylene	2006/05/05	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/05/04	0.0001	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/05/04	0.001	mg/L	No
Trifluralin	2006/05/04	0.001	mg/L	No
Vinyl Chloride	2006/05/05	0.0003	mg/L	No

**WELL F - LINDEN WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/02/22	0.0006	mg/L	No
Aldicarb	2006/02/22	0.0008	mg/L	No
Aldrin + Dieldrin	2006/02/22	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/02/22	0.0009	mg/L	No
Azinphos-methyl	2006/02/22	0.0005	mg/L	No
Bendiocarb	2006/02/22	0.002	mg/L	No
Benzene	2006/02/22	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/22	0.00001	mg/L	No
Bromoxynil	2006/02/22	0.0009	mg/L	No
Carbaryl	2006/02/22	0.002	mg/L	No
Carbofuran	2006/02/22	0.002	mg/L	No
Carbon Tetrachloride	2006/02/22	0.0003	mg/L	No
Chlordane (Total)	2006/02/22	0.000004	mg/L	No

Chlorpyrifos	2006/02/22	0.0005	mg/L	No
Cyanazine	2006/02/22	0.0005	mg/L	No
Diazinon	2006/02/22	0.0005	mg/L	No
Dicamba	2006/02/22	0.0004	mg/L	No
1,2-Dichlorobenzene	2006/02/22	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/22	0.0003	mg/L	No
(DDT) + metabolites	2006/02/22	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/22	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/22	0.0003	mg/L	No
Dichloromethane	2006/02/22	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/22	0.002	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/22	0.0004	mg/L	No
Diclofop-methyl	2006/02/22	0.0004	mg/L	No
Dimethoate	2006/02/22	0.0005	mg/L	No
Dinoseb	2006/02/22	0.00009	mg/L	No
Diquat	2006/02/22	0.007	mg/L	No
Diuron	2006/02/22	0.0008	mg/L	No
Glyphosate	2006/02/22	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/02/22	0.000004	mg/L	No
Linadane (Total)	2006/02/22	0.000001	mg/L	No
Malathion	2006/02/22	0.0005	mg/L	No
Methoxychlor	2006/02/22	0.000003	mg/L	No
Metolachlor	2006/02/22	0.0003	mg/L	No
Metribuzin	2006/02/22	0.0003	mg/L	No
Monochlorobenzene	2006/02/22	0.0003	mg/L	No
Paraquat	2006/02/22	0.001	mg/L	No
Parathion	2006/02/22	0.0003	mg/L	No
Pentachlorophenol	2006/02/22	0.002	mg/L	No
Phorate	2006/02/22	0.0005	mg/L	No
Picloram	2006/02/22	0.00009	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/22	0.0002	mg/L	No
Prometryne	2006/02/22	0.0003	mg/L	No
Simazine	2006/02/22	0.0005	mg/L	No
Temephos	2006/02/22	0.0008	mg/L	No
Terbufos	2006/02/22	0.0003	mg/L	No
Tetrachloroethylene	2006/02/22	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/02/22	0.002	mg/L	No
Triallate	2006/02/22	0.0003	mg/L	No
Trichloroethylene	2006/02/22	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/22	0.002	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/22	0.00009	mg/L	No
Trifluralin	2006/02/22	0.0003	mg/L	No
Vinyl Chloride	2006/02/22	0.0003	mg/L	No

**WELL G - PHARAND WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/02/24	0.001	mg/L	No
Aldicarb	2006/02/24	0.001	mg/L	No
Aldrin + Dieldrin	2006/02/24	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/02/24	0.0009	mg/L	No

Azinphos-methyl	2006/02/24	0.0008	mg/L	No
Bendiocarb	2006/02/24	0.002	mg/L	No
Benzene	2006/02/24	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/24	0.00001	mg/L	No
Bromoxynil	2006/02/24	0.001	mg/L	No
Carbaryl	2006/02/24	0.002	mg/L	No
Carbofuran	2006/02/24	0.002	mg/L	No
Carbon Tetrachloride	2006/02/24	0.0003	mg/L	No
Chlordane (Total)	2006/02/24	0.000004	mg/L	No
Chlorpyrifos	2006/02/24	0.0008	mg/L	No
Cyanazine	2006/02/24	0.0008	mg/L	No
Diazinon	2006/02/24	0.0008	mg/L	No
Dicamba	2006/02/24	0.0005	mg/L	No
1,2-Dichlorobenzene	2006/02/24	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/24	0.0003	mg/L	No
(DDT) + metabolites	2006/02/24	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/24	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/24	0.0003	mg/L	No
Dichloromethane	2006/02/24	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/24	0.001	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/24	0.0005	mg/L	No
Diclofop-methyl	2006/02/24	0.0005	mg/L	No
Dimethoate	2006/02/24	0.0008	mg/L	No
Dinoseb	2006/02/24	0.0001	mg/L	No
Diquat	2006/02/24	0.007	mg/L	No
Diuron	2006/02/24	0.001	mg/L	No
Glyphosate	2006/02/24	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/02/24	0.000004	mg/L	No
Linadane (Total)	2006/02/24	0.000004	mg/L	No
Malathion	2006/02/24	0.0008	mg/L	No
Methoxychlor	2006/02/24	0.00001	mg/L	No
Metolachlor	2006/02/24	0.0005	mg/L	No
Metribuzin	2006/02/24	0.0005	mg/L	No
Monochlorobenzene	2006/02/24	0.0003	mg/L	No
Paraquat	2006/02/24	0.001	mg/L	No
Parathion	2006/02/24	0.0005	mg/L	No
Pentachlorophenol	2006/02/24	0.001	mg/L	No
Phorate	2006/02/24	0.0008	mg/L	No
Picloram	2006/02/24	0.0001	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/24	0.0006	mg/L	No
Prometryne	2006/02/24	0.0005	mg/L	No
Simazine	2006/02/24	0.0008	mg/L	No
Temephos	2006/02/24	0.03	mg/L	No
Terbufos	2006/02/24	0.0005	mg/L	No
Tetrachloroethylene	2006/02/24	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/02/24	0.001	mg/L	No
Triallate	2006/02/24	0.0005	mg/L	No
Trichloroethylene	2006/02/24	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/24	0.001	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/24	0.0001	mg/L	No
Trifluralin	2006/02/24	0.0005	mg/L	No
Vinyl Chloride	2006/02/24	0.0003	mg/L	No

**WELL H - MICHELLE WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/02/22	0.0007	mg/L	No
Aldicarb	2006/02/22	0.0007	mg/L	No
Aldrin + Dieldrin	2006/02/22	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/02/22	0.0009	mg/L	No
Azinphos-methyl	2006/02/22	0.0005	mg/L	No
Bendiocarb	2006/02/22	0.001	mg/L	No
Benzene	2006/02/22	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/22	0.00001	mg/L	No
Bromoxynil	2006/02/22	0.001	mg/L	No
Carbaryl	2006/02/22	0.001	mg/L	No
Carbofuran	2006/02/22	0.001	mg/L	No
Carbon Tetrachloride	2006/02/22	0.0003	mg/L	No
Chlordane (Total)	2006/02/22	0.000004	mg/L	No
Chlorpyrifos	2006/02/22	0.0005	mg/L	No
Cyanazine	2006/02/22	0.0005	mg/L	No
Diazinon	2006/02/22	0.0005	mg/L	No
Dicamba	2006/02/22	0.0004	mg/L	No
1,2-Dichlorobenzene	2006/02/22	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/22	0.0003	mg/L	No
(DDT) + metabolites	2006/02/22	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/22	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/22	0.0003	mg/L	No
Dichloromethane	2006/02/22	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/22	0.003	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/22	0.0004	mg/L	No
Diclofop-methyl	2006/02/22	0.0004	mg/L	No
Dimethoate	2006/02/22	0.0005	mg/L	No
Dinoseb	2006/02/22	0.0001	mg/L	No
Diquat	2006/02/22	0.007	mg/L	No
Diuron	2006/02/22	0.0007	mg/L	No
Glyphosate	2006/02/22	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/02/22	0.000004	mg/L	No
Linadane (Total)	2006/02/22	0.000002	mg/L	No
Malathion	2006/02/22	0.0005	mg/L	No
Methoxychlor	2006/02/22	0.000004	mg/L	No
Metolachlor	2006/02/22	0.0004	mg/L	No
Metribuzin	2006/02/22	0.0004	mg/L	No
Monochlorobenzene	2006/02/22	0.0003	mg/L	No
Paraquat	2006/02/22	0.001	mg/L	No
Parathion	2006/02/22	0.0004	mg/L	No
Pentachlorophenol	2006/02/22	0.003	mg/L	No
Phorate	2006/02/22	0.0005	mg/L	No
Picloram	2006/02/22	0.0001	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/22	0.0003	mg/L	No
Prometryne	2006/02/22	0.0004	mg/L	No
Simazine	2006/02/22	0.0005	mg/L	No
Temephos	2006/02/22	0.0009	mg/L	No
Terbufos	2006/02/22	0.0004	mg/L	No

Tetrachloroethylene	2006/02/22	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/02/22	0.003	mg/L	No
Triallate	2006/02/22	0.0004	mg/L	No
Trichloroethylene	2006/02/22	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/22	0.003	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/22	0.0001	mg/L	No
Trifluralin	2006/02/22	0.0004	mg/L	No
Vinyl Chloride	2006/02/22	0.0003	mg/L	No

**WELL I - I WELL**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006/02/24	0.003	mg/L	No
Aldicarb	2006/02/24	0.0007	mg/L	No
Aldrin + Dieldrin	2006/02/24	0.000004	mg/L	No
Atrazine + N-dealkylated metabolites	2006/02/24	0.0009	mg/L	No
Azinphos-methyl	2006/02/24	0.002	mg/L	No
Bendiocarb	2006/02/24	0.001	mg/L	No
Benzene	2006/02/24	0.0003	mg/L	No
Benzo(a)pyrene	2006/02/24	0.00001	mg/L	No
Bromoxynil	2006/02/24	0.001	mg/L	No
Carbaryl	2006/02/24	0.001	mg/L	No
Carbofuran	2006/02/24	0.001	mg/L	No
Carbon Tetrachloride	2006/02/24	0.0003	mg/L	No
Chlordane (Total)	2006/02/24	0.000004	mg/L	No
Chlorpyrifos	2006/02/24	0.002	mg/L	No
Cyanazine	2006/02/24	0.002	mg/L	No
Diazinon	2006/02/24	0.002	mg/L	No
Dicamba	2006/02/24	0.0004	mg/L	No
1,2-Dichlorobenzene	2006/02/24	0.0003	mg/L	No
1,4-Dichlorobenzene	2006/02/24	0.0003	mg/L	No
(DDT) + metabolites	2006/02/24	0.000005	mg/L	No
1,2-Dichloroethane	2006/02/24	0.0003	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	2006/02/24	0.0003	mg/L	No
Dichloromethane	2006/02/24	0.0003	mg/L	No
2-4 Dichlorophenol	2006/02/24	0.001	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006/02/24	0.0004	mg/L	No
Diclofop-methyl	2006/02/24	0.0004	mg/L	No
Dimethoate	2006/02/24	0.002	mg/L	No
Dinoseb	2006/02/24	0.0001	mg/L	No
Diquat	2006/02/24	0.007	mg/L	No
Diuron	2006/02/24	0.0007	mg/L	No
Glyphosate	2006/02/24	0.01	mg/L	No
Heptachlor + Heptachlor Epoxide	2006/02/24	0.000004	mg/L	No
Linadane (Total)	2006/02/24	0.000003	mg/L	No
Malathion	2006/02/24	0.002	mg/L	No
Methoxychlor	2006/02/24	0.000008	mg/L	No
Metolachlor	2006/02/24	0.001	mg/L	No
Metribuzin	2006/02/24	0.001	mg/L	No
Monochlorobenzene	2006/02/24	0.0003	mg/L	No
Paraquat	2006/02/24	0.001	mg/L	No

Parathion	2006/02/24	0.001	mg/L	No
Pentachlorophenol	2006/02/24	0.001	mg/L	No
Phorate	2006/02/24	0.002	mg/L	No
Picloram	2006/02/24	0.0001	mg/L	No
Polychlorinated Biphenyls(PCB)	2006/02/24	0.0005	mg/L	No
Prometryne	2006/02/24	0.001	mg/L	No
Simazine	2006/02/24	0.002	mg/L	No
Temephos	2006/02/24	0.02	mg/L	No
Terbufos	2006/02/24	0.001	mg/L	No
Tetrachloroethylene	2006/02/24	0.0003	mg/L	No
2,3,4,6-Tetrachlorophenol	2006/02/24	0.001	mg/L	No
Triallate	2006/02/24	0.001	mg/L	No
Trichloroethylene	2006/02/24	0.0003	mg/L	No
2,4,6-Trichlorophenol	2006/02/24	0.001	mg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006/02/24	0.0001	mg/L	No
Trifluralin	2006/02/24	0.001	mg/L	No
Vinyl Chloride	2006/02/24	0.0003	mg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Cadmium	0.00333	mg/L	2007/03/07

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)**