



NOTES:

1. CONCRETE TO BE AS PER GSS 351.
2. UTILITY ISOLATION IN SIDEWALKS – GSSD-310.040.
3. EXPANSION JOINTS ARE REQUIRED AT BOTH SIDES OF THE DRIVEWAY. THESE JOINTS SHALL CONTINUE THROUGH THE CURB AREA IF THE DISTANCE FROM THE PREVIOUS JOINT IS LESS THAN 1.5 m. THIS DISTANCE SHALL BE ADDED TO THE NEXT BAY AND A DUMMY JOINT PLACED AT MID-SPAN. DUMMY JOINTS ARE REQUIRED IN DRIVEWAYS AT INTERVALS OF 1.5 m, BUT IN NO CASE LESS THAN 1 m.
- IF THE DRIVEWAY IS GREATER THAN 6 m IN WIDTH, AN EXPANSION JOINT WILL BE REQUIRED AT MID-SPAN AND CONTINUE THROUGH THE CURB AREA. DEPTH OF CONCRETE SHALL TAPER TO THE NORMAL DEPTH FOR A DISTANCE OF 1.5 m AT EACH SIDE OF DRIVEWAY.
4. SIDEWALK THICKNESS AT RESIDENTIAL DRIVEWAYS SHALL BE 150 mm. AT COMMERCIAL AND INDUSTRIAL DRIVEWAYS, THE THICKNESS SHALL BE 200 mm.
5. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.

DISCLAIMER OF WARRANTY

The data is provided "as-is", without warranty of any kind either expressed or implied. Any and all liabilities for damage, direct or indirect, however caused, and resulting in any way by use of the supplied data is the full and final responsibility of the user.

COPYRIGHT
 All rights are reserved. No part of the supplied data may be reproduced, or transmitted to others, in any form or by any means, without the written permission of the CITY OF GREATER SUBURBY.



MONOLITHIC CURB AND CONCRETE SIDEWALK

DRAWN BY: STS/APP	REV No.: 2
DATE: 2003-03-03	REV DATE: 2019-05-14
SCALE: NTS	CAD/FILE No.: A1945-1 (1 OF 1)
APP'D:	GSSD-310.015