



NOTES:

1. THIS STANDARD TO BE READ IN CONJUNCTION WITH GSSS 441.
2. FOR POLYETHYLENE SERVICE PIPE REFER TO GSSD-1104.020.
3. DOUBLE SERVICES ARE NOT PERMITTED WITHOUT WRITTEN APPROVAL OF CITY ENGINEER.
4. ALL SERVICE CONNECTIONS SHALL BE SINGLE TAP ONLY, UTILIZING APPROPRIATELY SIZED FITTINGS.
5. CAPREOL AND LEVACK SERVICES SHALL BE INSULATED. SEE GSSD-1104.011.
6. FOR WATER SERVICE IN ROCK TRENCH SEE GSSD-1104.011
7. TRENCH CONSTRUCTION AND PIPE BEDDING AS PER GSSD-1227.010.
8. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.
9. CURB STOP SHALL HAVE CORROSION PROTECTION PRIOR TO PLACEMENT OF SERVICE BOX.
10. TRACER WIRE AS PER GSSD-1110.000.
11. CORROSION PROTECTION AS PER GSSS 442

DISCLAIMER OF WARRANTY
The data is provided "as-is", without warranty of any kind either expressed or implied. Any and all liabilities for damage, direct or indirect, however caused, and resulting in any way by use of the supplied data is the full and final responsibility of the user.

COPYRIGHT
All rights are reserved. No part of the supplied data may be reproduced, or transmitted to others, in any form or by any means, without the written permission of the CITY OF GREATER SUDBURY.



**WATER SERVICE CONNECTION
DETAIL IN EARTH TRENCH**
20 mm TO 50 mm DIA SIZES

DRAWN BY: RF/SAG/KLR	REV No: 6
DATE: 2003-03-03	REV DATE: 2019-02-25
SCALE: NTS	CAD/FILE No.: A1968-1 (1 OF 1)
APP'D: M. FRAYNE	GSSD-1104.010