



**NOTES**

1. EXPANSION JOINTS AS PER GSSD-310.010 FOR THE SIDEWALK AND RETAINING WALL TO BE COMMON.
2. CLASS OF CONCRETE: 32 MPa AT 28 DAYS.
3. UNCOATED 150 mm SQUARE STEEL WIRE FABRIC (No.3.8) FOR CONCRETE REINFORCEMENT CONFORMING TO C.S.A. G30.5, 1998 SHALL BE PLACED IN THE SIDEWALK AND RETAINING WALL.
4. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.

**DISCLAIMER OF WARRANTY**  
 The data is provided "as-is", without warranty of any kind either expressed or implied. Any and all liabilities for damage, direct or indirect, however caused, and resulting in any way by use of the supplied data is the full and final responsibility of the user.

**COPYRIGHT**  
 All rights are reserved. No part of the supplied data may be reproduced, or transmitted to others, in any form or by any means, without the written permission of the CITY OF GREATER SUDBURY.



**MONOLITHIC  
 CONCRETE SIDEWALK  
 AND RETAINING WALL**

|                     |                                |
|---------------------|--------------------------------|
| DRAWN BY: STS/FRANK | REV No: 1                      |
| DATE: 2003-03-03    | REV DATE: JAN/2013             |
| SCALE: NTS          | CAD/FILE No.: A1931-1 (1 OF 1) |
| APP'D:              | <b>GSSD-310.018</b>            |