



NOTES:

1. THIS DRAWING TO BE READ IN CONJUNCTION WITH GSSD-1006.010, GSSD-1006.020, GSSD-1104.010 AND GSSD-1227.010.
2. CROWLE TEST FITTING TO BE SEALED WITH AN INTERNAL-EXPANDING PLUG (UPSTREAM END) AND METAL STRAPPED AROUND EXTERIOR WHEN BUILDING SEWERS ARE NOT CONNECTED.
3. PIPE SEPARATION WILL VARY FROM THAT SHOWN, WHEN THE SEWER MAIN EXCEEDS 300 mm IN DIAMETER.

USE OF DUAL SERVICE CONNECTION REQUIRES WRITTEN APPROVAL OF THE SEWER AND WATER ENGINEER.

DRAWN BY: STS/FRANK	REV No:
DATE: 2003-03-03	REV DATE:
SCALE: NTS	CAD/FILE No.: A1956-1 (1 OF 1)
APP'D:	GSSD-1006.030

DUAL SERVICE CONNECTIONS IN A COMMON TRENCH (SEWER & WATER)



DISCLAIMER OF WARRANTY
 The data is provided "as-is", without warranty of any kind either expressed or implied. Any and all liabilities for damage, direct or indirect, however caused, and resulting in any way by use of the supplied data is the full and final responsibility of the user.

COPYRIGHT
 All rights are reserved. No part of the supplied data may be reproduced, or transmitted to others, in any form or by any means, without the written permission of the CITY OF GREATER SUDBURY.