



**NOTES:**

1. UPPER AND LOWER ASSEMBLIES TO BE ADEQUATELY BRACED WHILE BACKFILLING, AND MUST REMAIN PLUMB.
2. CLEANOUT COVER SHALL BE OF STD. IRON FOR EASE OF LOCATING WITH DIP NEEDLE (SEE STD. GSSD-1101.020).
3. DEPTH OF WYE MUST BE ADEQUATE TO PERMIT CONNECTION TO OUTLET PIPE AND MAINTAIN THE MINIMUM GRADE OF 2%.
4. THIS STANDARD SHALL APPLY FOR SEWER CONNECTIONS WHEN THE LENGTH OF SERVICE EXCEEDS 30 METRES. LOCATION OF VERTICAL CLEANOUT SHALL BE AS SPECIFIED BY THE ENGINEER.
5. THIS STANDARD TO BE READ IN CONJUNCTION WITH CITY OF GREATER SUDBURY STANDARD DRAWINGS GSSD-1006.030 AND GSSD-1227.010.
6. ALL PVC PIPE SHALL BE S.D.R. 28.
7. BACKFILL MATERIAL SHALL CONSIST OF COMPACTED SAND BEDDING IN 300 mm LAYERS.
8. COVER SHALL BE 100mm BELOW FINISHED GRADE IN SODDED OR GRAVEL AREAS. COVER SHALL BE FLUSH WITH FINISHED GRADE IF IN ASPHALT OR CONCRETE.



**STANDARD VERTICAL CLEANOUT  
ON A SANITARY SEWER SERVICE**

DRAWN BY: SAG	REV No: 2
DATE: 2003-03-03	REV DATE: JAN/2013
SCALE: NTS	CAD/FILE No.: A1957-1 (1 OF 1)
APP'D:	<b>GSSD-1025.010</b>

DISCLAIMER OF WARRANTY : The data is provided "as-is", without warranty of any kind either expressed or implied. Any and all liabilities for damage, direct or indirect, however caused, and resulting in any way by use of the supplied data is the full and final responsibility of the user.

COPYRIGHT : All rights are reserved. No part of the supplied data may be reproduced, or transmitted to others, in any form or by any means, without the prior written permission of the CITY OF GREATER SUDBURY.