

WASTEWATER STEWARDSHIP REPORT - 2015 4th QUARTER

DATE	TIME (24H clock)	DURA- TION	LOCATION	LOCATION DESCRIPTOR	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
07-Oct-15	15:35	0.5 hrs	OTHER	Parkdale Dr., Val Caron	OTHER	Receptor not impacted	Whitson River	0.1	n/a	Sanitary sewer overflow	blockage in sewer	MINOR release of wastewater contained on site