

WASTEWATER STEWARDSHIP REPORT

June - July 2016

DATE	TIME <small>(24H clock)</small>	DURA- TION	LOCATION	LOCATION DESCRIPTOR	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
01-Jun-16	13:30	1 hr	OTHER	1394 Kingsway	Other	Receptor not impacted	n/a	0.3	0.5 kg of HTH	Sanitary sewer overflow	Blockage in Manhole	
09-Jul-16	12:45	15 hrs	Coniston WWTP	Coniston	Plant bypass: flow exceeds design capacity	Receptor not impacted	Coniston Creek	1,327.0	1.91 lbs of Cl2	Heavy rain	Heavy Flows	Sampled
09-Jul-16	9:00	2:05 hrs	Lively WWTP	Lively	Plant bypass: flow exceeds design capacity	None	Meatbird Creek	100.0	5 kgs of Cl2	Heavy rain	Heavy Flows	Sampled