



1st Quarter
2022

REVISED: 18-Mar-22

PLANT BYPASS / OVERFLOW LOG

| # | DATE | TIME (24H clock) | DURATION | LOCATION | LOCATION DESCRIPTOR / ADDRESS | Pit / LS / Other | TYPE OF OCCURRENCE | SENSITIVE RECEPTOR | RECEIVING STREAM ID | VOL (m ³) | Est or Meas? | LEVEL OF TREATMENT RECEIVED | REASON FOR EVENT | OUTSIDE INFLUENCES | COMMENTS / RELEVANCE |
|---|-----------|---------------------|----------|--------------|-------------------------------------|---------------------|----------------------------|--------------------|------------------------|-----------------------|-----------------|-----------------------------------|---------------------|-----------------------|---|
| 1 | 16-Feb-22 | 3:20 | 4 hrs | Sudbury WWTP | 367 Morris | Collection | Collection system overflow | None | None | 0.5 | Est | none | Maintenance | | Self Contained on st, Vactor for clean up |
| 2 | 21-Feb-22 | unknown | unknown | Lively WWTP | 231 First Ave | Lively WWTP | Plant overflow | None | None | 5.0 | Est | none | Equipment (failure) | | Contained on property, loader/pumper clean up and area disinfected with HTH |