

**PLANT BYPASS / OVERFLOW LOG**

REVISED: 8-Apr-20

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m <sup>3</sup> )	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
3	09-Mar-20	20:45	12 hrs	Coniston WWTP	Coniston Contact Chamber	plt	Plant bypass: flow exceeds design capacity	Receptor not impa	Coniton Creek	768.0	meas	Full Treatment	Heavy rain	spring runoff	disinfection procedures followed;
4	13-Mar-20	5:00	11 hrs	Coniston WWTP	Coniston Contact Chamber	plt	Plant bypass: flow exceeds design capacity	Receptor not impa	Coniton Creek	704.0	meas	Full Treatment	Heavy rain	spring runoff	disinfection procedures followed;
5	17-Mar-20	6:55	2hrs 5mins	Chelmsford WWTP	265 Laurette St	plt	Plant bypass: flow exceeds design capacity	Receptor not impa	Whitson Creek	173.4	meas	Full Treatment	Heavy rain	spring runoff	MINOR release of wastewater
6	20-Mar-20	1:45	17 hrs	Coniston WWTP	Coniston Contact Chamber	plt	Plant bypass: flow exceeds design capacity	Receptor not impa	Coniton Creek	1,088.0	meas	Full Treatment	Heavy rain	spring runoff	disinfection procedures followed;
7	27-Mar-20	5:00	3.5 hrs	Sudbury WWTP	1271 Kelly Lake Road	plt	Plant bypass	Receiving water	Junction Creek	6,770.0	meas	screening and d2 52.5kg	Heavy rain	spring runoff	disinfection procedures followed;
8	27-Mar-20	1:30	7 hrs	Sudbury WWTP	1271 Kelly Lake Road	plt	Plant bypass: flow exceeds design capacity	Receiving water	Junction Creek	2,750.0	meas	screening and d2 52.5kg	Heavy rain	spring runoff	disinfection procedures followed;
9	27-Mar-20	14:20	116 hrs	Sudbury WWTP	1271 Kelly Lake Road	plt	Plant bypass	Receiving water	Junction Creek	255,010.0	meas	screening and d2 52.5kg	Heavy rain	spring runoff	disinfection procedures followed;