



1st Quarter
2022

REVISED:

5-Apr-22

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
3	06-Mar-22	13:25	2 hrs	Valley East WWTP	1861 Yorkshire Ave	Plant	Plant overflow	None	none	20.00	est	Full Treatment	Equipment (failure)		Contained to property, liquid was pumped back to well, and area was disinfected with HTH
4	06-Mar-22	13:01	2 hrs	Lively WWTP	231 First Ave	Lively WWTP	Plant overflow	None	None	76.0	est	Full Treatment	Spring run-off		Full treatment
5	06-Mar-22	14:00	6.5 hr	Coniston WWTP	121 Govt Rd	Plant	Plant bypass: flow exceeds design capacity	None	Coniston Creek	300.0	est	Full Treatment	Spring run-off		Full treatment
6	17-Mar-22	14:40	1.5 Hr	Levack WWTP	45 High St	Plant	Plant bypass	None	Onaping River	122.0	est	Disinfection	Equipment (failure)		Bypass of clarifier, disinfection in contact chamber
7	20-Mar-22	14:27	5h 24min	Chelmsford WWTP	265 Laurette St	plant	Plant bypass: flow exceeds design capacity	None	Whitson River	382.0	est	Full Treatment	Spring run-off		Full Treatment
8	17-Mar-22	18:05	56hrs	Coniston WWTP	121 government rd.	plant	Plant bypass: flow exceeds design capacity	none	Coniston Creek	4,394.0	est	Full Treatment	Spring run-off		Full treatment
9	31-Mar-22	18:00	6.5 hr	Sudbury WWTP	1271 Kelly Lake Road	plant	Plant bypass: flow exceeds design capacity	none	junction Creek	20,145.0	est	clorinate/ declorinate	Spring run-off		Full treatment
10	31-Mar-22	12:10	6 hr	Lively WWTP	231 ffirst Street	plant	Plant bypass: flow exceeds design capacity	none	meatbird creek	7,221.0	est	clorinate/ declorinate	Spring run-off		clorinate/ declorinate
11	31-Mar-22	20:33	8 hr	Walden WWTP	1425 MR 55	plant	Plant overflow	none	simon creek	3,132.0	est	Full Treatment	Spring run-off		clorinate/ declorinate
12	31-Mar-22	14:30	3 hrs	Levack WWTP	45 High Street	Plant	Plant bypass: flow exceeds design capacity	None	Onaping River	100.3	est	Full Treatment	Heavy rain		FullTreatment
13	31-Mar-22	13:00	2 hrs	Chelmsford WWTP	265 Laurette Street	Plant	Plant bypass: flow exceeds design capacity	None	Whitson Creek	2,658.0	est	Full Treatment	Heavy rain		Full Treatment
14	31-Mar-22	13:00	3 hrs	Azilda WWTP	564 St Agnes Street	Plant	Plant bypass: flow exceeds design capacity	None	Pilon Creek Outfall	3,102.0	est	Full Treatment	Heavy rain		Full Treatment
15	31-Mar-22	12:30	7 hrs 10 min	Coniston WWTP	121 Govt Rd	Plant	Plant bypass: flow exceeds design capacity	None	Coniston Creek	889.0	est	Full Treatment	Heavy rain		Full Treatment
16	31-Mar-22	9:30	12 hrs	Coniston WWTP	121 Govt Rd	Plant	Plant bypass: flow exceeds design capacity	None	Coniston Creek	768.0	est	Full Treatment	Heavy rain		Full Treatment