



2024

REVISED: 12-Apr-24

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
3	05-Mar-24	6:00	52 hr	Coniston WWTP	121 Government Rd	PT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	6,604.0	Est	Disinfection	Spring run off	Rain melting snow	Samples taken
4	06-Mar-24	16:00	16 hr	Sudbury WWTP	1275 Kelly Lk Rd	PT	Plant bypass	Receptor not impacted	Junction Creek	33,665.0	Mea	Disinfection	Spring run off	Rain melting snow	Samples taken
5	09-Mar-24	16:30	13.5 hr	Sudbury WWTP	1275 Kelly Lk Rd	PT	Plant bypass	Receptor not impacted	Junction Creek	33,665.0	Mea	Disinfection	Spring run off	Rain melting snow	Samples taken