



2nd Quarter
2022

REVISED: 3-May-22

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	RECEIVING STREAM ID	VOL (m ³)	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	COMMENTS / RELEVANCE
17	06-Apr-22	23:00	2 hrs 30 min	Levack WWTP	45 High Street Levack	PLT	Plant bypass: flow exceeds design capacity	Onaping River	650 m3	Full Treatment Disinfection H	Heavy rain	Spring Run off
18	06-Apr-22	23:35	33 hr	Sudbury WWTP	1271 Kelly Lake Road	PLT	Plant bypass	junction Creek	123,448 m3	bar screen disinfection	Heavy rain	Spring run off
19	06-Apr-22	22:00	20 hr	Walden WWTP	1425 MR 55	PLT	Plant bypass	Simon Creek	3958 m3	disinfection	Heavy rain	Spring run off
20	06-Apr-22	20:50	18 hr 50 min	Lively WWTP	231 First Street	PLT	Plant bypass	Meatbird Creek	3166 m3	disinfection	Heavy rain	Spring run off
21	07-Apr-22	14:20	17 hrs 30 min	Chelmsford WWTP	265 Laurette St	PLT	Plant bypass: flow exceeds design capacity	Whitson Creek	2277m3	Full Treatment Disinfection H	Heavy rain	Spring run off/ Equipment Failure
22	06-Apr-22	22:00	34 Hrs	Coniston WWTP	121 Gov't rd	PLT	Plant bypass	Coniston Creek	4,699.0	Disinfection	Heavy Rain	Spring run off
23	07-Apr-22	8:15	1 hr 15 mins	Government Rd LS	3 Govt rd	LS	Collection system overflow	Coniston Creek	3.4 M3	Disinfection	Heavy rain	Spring Run Off ? Heavy Rain
24	06-Apr-22	20:30	66hrs 30 min	Azilda WWTP	564 St Agnes Street	PLT	Plant bypass: flow exceeds design capacity	Pilon Creek	8743m3	Full Treatment Disinfection	Heavy rain	Spring Run Off
25	14-Apr-22	6:35	17hrs 30min	Azilda WWTP	564 Agnes Street	PLT	Plant bypass: flow exceeds design capacity	Pilon Creek	14,513.0	Full Treatment- Disinfection	Heavy rain	Spring Run off
26	05-Apr-22	18:45	131.00	Coniston WWTP	121 Gov't rd	plt	Plant bypass: flow exceeds design capacity	Coniston Creek	8688 m3	Full Treatment_Disinfection	Heavy rain	Spring Run off
27	24-Apr-22	21:45	1hr 50 min	Walden WWTP	1425 MR 55	plant	Plant overflow	simon creek	278 m3	Full Treatment	Heavy rain	clorinate/ declorinate
28	24-Apr-22	22:13	1hr 30mins	Coniston WWTP	121 Govt rd			coniston Creek	191.0	Disinfection	Heavy rain	Spring run off / Heavy rain
29	22-Apr-22	8:15	120 hrs	Wahnapiatae Lagoon				Wahn River	65.0		Heavy rain	spring run off/heavy rain /snow melt
30	24-Apr-22	19:45	29hrs	Azilda WWTP	564 Agnes Street	PLT	Plant bypass: flow exceeds design capacity	Pilon Creek	2,189.0	Full Treatment- Disinfection	Heavy rain	Spring run off/Rain
31	April 20-22	15:05	75.00	Coniston WWTP	121 Govt rd	plt	Plant bypass: flow exceeds design capacity	Coniston Creek	4,800.0	full Treatment/ Disinfection	Heavy rain	Spring Run off? Rain