



PLANT BYPASS / OVERFLOW LOG

2024

REVISED: 30-Apr-24

| #  | DATE      | TIME<br>(24H clock) | DURATION | LOCATION       | LOCATION DESCRIPTOR /<br>ADDRESS | Plt / LS /<br>Other  | TYPE OF<br>OCCURRENCE         | SENSITIVE<br>RECEPTOR | RECEIVING<br>STREAM ID | VOL (m <sup>3</sup> ) | Est or<br>Meas<br>? | LEVEL OF TREATMENT<br>RECEIVED | REASON FOR EVENT | OUTSIDE<br>INFLUENCES                              | COMMENTS / RELEVANCE           |
|----|-----------|---------------------|----------|----------------|----------------------------------|----------------------|-------------------------------|-----------------------|------------------------|-----------------------|---------------------|--------------------------------|------------------|----------------------------------------------------|--------------------------------|
| 6  | 04-Apr-24 | 16:40               | 82.5 hr  | Coniston WWTP  | 121 Government Rd                | Plant                | Plant bypass                  | Receptor not impacted | Coniston Creek         | 6,225.0               | Est                 | Disinfection                   | Spring run off   | Rain                                               | Samples taken                  |
| 7  | 12-Apr-24 | 10:05               | 48hrs    | Coniston WWTP  | 121 Government Rd                | Plant                | Plant bypass                  | Receptor not impacted | Coniston Creek         | 3,941.0               | Est                 | Disinfection                   | Spring run off   | Heavy Rain                                         | Samples taken                  |
| 8  | 12-Apr-24 | 15:00               | 39.5hrs  | Sudbury WWTP   | 1271 Kelly Lake Rd               | Plant                | Plant bypass                  | Receptor not impacted | Junction Creek         | 153 287               | Mea                 | Disinfection                   | Spring run off   | Heavy Rain                                         | Samples taken                  |
| 9  | 12-Apr-24 | 12:45               | 69hrs    | Lively WWTP    | 231 First Ave                    | Plant                | Plant bypass                  | Receptor not impacted | Meatbird Creek         | 9,110.6               | Mea                 | Disinfection                   | Spring run off   | Heavy Rain                                         | Samples taken                  |
| 10 | 12-Apr-24 | 23:30               | 2.8hrs   | Horobin Bypass | 733 St Clair St                  | Collection<br>System | Collection system<br>overflow | Receptor not impacted | Junction Creek         | 7,000.0               | Est                 | None                           | Spring run off   | Heavy Rain                                         | Discharge under water          |
| 11 | 15-Apr-24 | 9:23                | 3.7 hrs  | Sudbury WWTP   | 2286 Algonquin Road              | Collection<br>System | Collection system<br>overflow | None                  | Enviro (ditch/catc     | 1100 L                | Est                 | To Environment                 | Maintenance      | Blockage in<br>sewermain fully<br>restricting flow | Residual chlorine from hydrant |
| 12 | 29-Apr-24 | 19:35               | 12 hrs   | Coniston WWTP  | 121 Government Rd                | Plant                | Plant bypass                  | Receptor not impacted | Coniston Creek         | 1,175.0               | Est                 | Disinfection                   | Heavy Rain       | Heavy Rain                                         | Samples Taken                  |
| 13 | 29-Apr-34 | 18:30               | 4 hrs    | Lively WWTP    | 231 First Ave                    | Plant                | Plant bypass                  | Receptor not impacted | Meatbird Creek         | 1,633.0               | Est                 | Disinfection                   | Heavy Rain       | Heavy Rain                                         | Samples Taken                  |