

PLANT BYPASS / OVERFLOW LOG 2022

REVISED: 1-Aug-22

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT
34	July 24/22	18:03	4hrs 40min	Coniston WWTP	121 Government Rd	PIT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	438.0	EST	Full Treatment	Heavy rain
35	July 28/22	9:40	4hrs 55min	Coniston WWTP	121 Government Rd	Plt	Plant bypass: flow exceeds design capacity	None	Coniston Creek	73.0	est	Full Treatment	Heavy rain