



**PLANT BYPASS / OVERFLOW LOG**

**3rd Quarter 2020**

REVISED: **29-Aug-20**

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m <sup>3</sup> )	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT
29	02-Aug-20	15:39	2HRS	Lively WWTP	231 First Ave Lively	plt	Plant bypass: flow exceeds design capacity	Receiving water	Meatbird Creek	251.0	Est	Full Treatment	Heavy rain
30	02-Aug-20	16:25	2 Hrs	Walden WWTP	1425 RR 55 naughton	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Simon Creek	1,087.0	Est	Full Treatment	Heavy rain
31	29-Aug-20	5:40	10 hrs	Coniston WWTP	121 Government Rd.	plt	Plant bypass: flow exceeds design capacity	Receiving water	Coniton Creek	2,880.00	meas	Full Treatment	Heavy rain