



**3rd Quarter  
2022**

REVISED: 19-Sep-22

**PLANT BYPASS / OVERFLOW LOG**

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m <sup>3</sup> )	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	COMMENTS / RELEVANCE
36	Aug 7/2022	15:31	7hrs 39min	Coniston WWTP	121 Government Rd	Plant bypass: flow exceeds design capacity	NONE	Coniston Creek	142.0	Est	Full Treatment	Heavy rain	
37	Aug 9/2022	16:12	8 hrs 38 min	Coniston WWTP	121 Government Rd	Plant bypass: flow exceeds design capacity	None	Coniston Creek	111.0	Est	Full Treatment	Heavy rain	