



4th Quarter
2020

REVISED: 16-Nov-20

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
38	23-Oct-20	5:49	28 hrs	Sudbury WWTP	1275 Kelly Lake Rd	Plt	Plant bypass: flow exceeds design capacity	none	Junction Creek	117,190.0	meas	Partial Treatment	Maintenance		
39	23-Oct-20	2:30	5.5 hr	Walden WWTP	1425 RR 55 naughton	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Simon Creek	1,943.0	Est	Full Treatment	Heavy rain		
40	23-Oct-20	3:15	10 hrs	Lively WWTP	231 First Ave Lively	plt	Plant bypass: flow exceeds design capacity	Receiving water	Meatbird Creek	251.0	Est	Partial Treatment	Heavy rain		
41	23-Oct-20	3:28	46hrs 19m	Azilda WWTP	564 Agnes St.	plt	Plant bypass: flow exceeds design capacity	Receiving water	Pilon Creek	3,710.0	meas	Full Treatment	Heavy rain		
42	23-Oct-20	1:16	4hrs 35m	Levack WWTP	45 High St.	plt	Plant bypass: flow exceeds design capacity	Receiving water	Onaping Creek	462.0	meas	Full Treatment	Heavy rain		
43	23-Oct-20	3:04	66hrs 36m	Chelmsford WWTP	265 Laurette St Chelmsford	plt	Plant bypass: flow exceeds design capacity	Receiving water	Whitson Creek	1,457.0	meas	Full Treatment	Heavy rain		
44	Oct 23-20	4:15	28.2 hrs	Coniston WWTP	121 Government Rd.	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Coniton Creek	3,356.0	Est	Partial Treatment	Heavy rain		
45	Oct. 24-20	12:00	29 hrs	Coniston WWTP	121 Government Rd.	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Coniston Creek	1,536.0	Est	Full Treatment	Heavy rain		
46	Oct. 31-20	8:24	14 hr	Coniston WWTP	121 Government Rd.	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Coniston Creek	896.0	Est	Full Treatment	Heavy rain		