

PLANT BYPASS / OVERFLOW LOG 4th Quarter 2022 REVISED: 17-Oct-22

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT
38	16-Oct-22	8:30	1hr 42min	Sudbury WWTP	325 Fourth	Collection	Collection system overflow	Receiving water	Ramsey	0.4	Est	none	Sanitary sewer overflow
39	17-Oct-22	21:00	16 hr	Coniston WWTP	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Cree	1,024.0	EST	Full Treatment	Heavy rain