



4th Quarter
2020

REVISED: 16-Nov-20

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
47	16-Nov-20	0:10	5 hr	Sudbury WWTP	1275 Kelly Lake Rd	Plt	Plant bypass: flow exceeds design capacity	none	Junction Creek	117,190.0	meas	Full Treatment	Maintenance		
48	15-Nov-20	16:52	6hrs 30m	Azilida WWTP	564 Agnes St.	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Pilon Creek	3,715.0	meas	Full Treatment	Heavy rain		
49	15-Nov-20	9:55	2.33 hr	Lively WWTP	231 First Ave Lively	plt	Plant bypass: flow exceeds design capacity	Receiving water	Meatbird Creek	270.0	Est	Full Treatment	Heavy rain		
50	15-Nov-20	16:10	15 hrs	Coniston WWTP	121 Government Rd.	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Coniston Creek	1,905.0	Est	Partial Treatment	Heavy rain		
51	15-Nov-20	11:53	20hrs 10min	Coniston WWTP	121 Government Rd.	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Coniston Creek	1,280.0	Est	Full Treatment	Heavy rain		
52	16-Nov-20	10:15	218 Hrs	Wahnapiatae Lagoon		Lagoon	OTHER	Receiving water	Marsh Land /River	540 L	Est	Partial Treatment	Heavy Rain		