



**PLANT BYPASS / OVERFLOW LOG**

**4th Quarter 2020**

REVISED: 24-Mar-21

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m <sup>3</sup> )	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT
53	24-Dec-20	9:20	4.25hrs	Coniston WWTP	121 Government Rd.	PLT	Plant bypass: flow exceeds design capacity	Receiving water	Coniston Creek	157.0	Est	Full Treatment	Heavy rain
54	24-Dec-20	4:45	2hrs	Levack WWTP	45 High St.	PLT	Plant bypass: flow exceeds design capacity	Receiving water	Onaping Creek	324.0	meas	Full Treatment	Heavy rain
55	30-Dec-22	12:30	2hrs	Sudbury WWTP	36 Orell, Garson	Collection	Collection system overflow	Receptor not impacted	Swamp/Wetland feeding to Junction Creek	7.2	est	To environment	Sanitary sewer overflow