



**PLANT BYPASS / OVERFLOW LOG**

**4th Quarter 2022**

REVISED: 25-Jan-23

| #  | DATE      | TIME<br>(24H clock) | DURATION   | LOCATION        | LOCATION<br>DESCRIPTOR /<br>ADDRESS | Plt / LS /<br>Other | TYPE OF OCCURRENCE                         | SENSITIVE RECEPTOR | RECEIVING<br>STREAM ID | VOL (m <sup>3</sup> ) | Est or<br>Meas? | LEVEL OF<br>TREATMENT<br>RECEIVED | REASON FOR EVENT        |
|----|-----------|---------------------|------------|-----------------|-------------------------------------|---------------------|--|--------------------|------------------------|-----------------------|-----------------|-----------------------------------|-------------------------|
| 38 | 16-Oct-22 | 8:30                | 1hr 42min  | Sudbury WWTP    | 325 Fourth                          | Collection          | Collection system overflow                 | Receiving water    | Ramsey                 | 0.4                   | Est             | none                              | Sanitary sewer overflow |
| 40 | 26-Dec-22 | 11:15               | unknown    | Chelmsford WWTP | 265 Laurette                        | plt                 | Plant overflow                             | none               | NA                     | <1                    | est             | Disinfection                      | Equipment (failure)     |
| 41 | 30-Dec-22 | 14:10               | 3hr 15 min | Coniston WWTP   | 121 Government Rd                   | PLT                 | Plant bypass: flow exceeds design capacity | None               | Coniston Creek         | 730.0                 | est             | Disinfection                      | Heavy rain              |