

		T BYPAS		RFLOW LOG	3rd Quarter REV 2021				REVISED:	13-Oct-21					
#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
12	14-Jul-21	19:40	1hr 33m	Levack WWTP	45 High St.	Plant	Plant bypass: flow exceeds design capacity	None	Onaping River	57.0	Scada	Full Treatment	Heavy rain	None	
13	24-Jul-21	15:00	4hrs	Lively WWTP	231 First Ave	Plant	Plant bypass: flow exceeds design capacity	None	Meatbird Creek	125.0	SCADA	Full Treatment	Heavy Rain	None	
14	24-Jul-21	18:30	9 hrs	Coniston WWTP	121 Govt Rd	Plant	Plant bypass: flow exceeds design capacity	None	Coniston Creek	617.0	Scada	Partial Treatment	Heavy rain	None	
15	29-Jul-21	17:30	2 hrs	Valley East WWTP	2943 MR 80	Mannole	Collection system overflow	None	Asphalt Entrance	1.0	EST	Vacuum Truck	OTHER	None	