



1st Quarter
2021

REVISED: 14-May-21

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
2	05-Mar-21	13:20	20 mins	Chelmsford WWTP	265 Laurette	Road	Collection system overflow	None	None	8.0	est	HTH	Equipment (failure)	none	spill
3	11-Mar-21	12:57	7hrs 40 mins	Walden WWTP	1425 MR55	Pit	Collection system overflow	Receiving water	Simon Creek	5,080.0	Meas	Full Treatment	Heavy rain	none	
4	11-Mar-21	11:30	13Hrs	Coniston WWTP	121 Gov't Rd	Plant	Collection system overflow	None	none	832.0	est	Full Treatment	Heavy rain	none	
5	28-Mar-21	10:20	17.50	Coniston WWTP	121 Gov't Rd	Plant	Collection system overflow	none	none	1,120.0	est	Full Treatment	Heavy rain	none	
7	28-Mar-21	12:10	3.5hrs	Sudbury WWTP	609 Notre-Dame	Forcemain	Force main break	None	environment	13.8	est	Disinfected	Maintenance	none	