



2rd Quarter
2021

REVISED: 8-Jul-21

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
6	04-May-21	16:00	18hrs	Capreol Lagoon	99 Lakeshore	Lagoon	Spill	None	none	619.0	est	Disinfection	Equipment (failure)	Rain	Spill over berm
8	13-May-21	15:30	1.5hrs	Sudbury WWTP	Martindale Easement	MH	Collection system overflow	Receiving water	Junction Creek	3.6	est	none	Maintenance	none	
9	19-May-21	16:45	.5hrs	Sudbury WWTP	86 Elm St.	Manhole	Collection system overflow	None	none	0.04	Est	none	Sanitary sewer overflow	none	Blocked Sewer Main. Main cleared on it's own
10	21-May-21	9:30	4 days, 2hrs 50mins	Azilda WWTP	299 Ste. Anges	Other	Force main break	None	none	5.0	Est	Disinfection	Equipment (failure)	none	remained on asphalt roadway
11	05-May-21	21:30	unknown	Sudbury WWTP	O'Neil West Easement	Other	Collection system overflow	none	none	unknown	na	none	Spring run-off	beaver dam	Due to the sewer main being under water because of a beaver dam, it is unknown if any of the manholes surcharged.