



3rd Quarter
2021

REVISED: 13-Oct-21

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
18	13-Oct-21	20:04	11hrs 30min	Coniston WWTP	121 Govt Rd	Plant	Plant bypass: flow exceeds design capacity	None	Coniston Creek	736.0	Scada	Full Treatment	Heavy rain	None	