



2nd Quarter
2023

REVISED: 1-May-23

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	LEVEL OF TREATMENT RECEIVED
03	03-Apr-23	17:40	2hr 50 min	Coniston WWTP	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	380.00	disinfection
04	06-Apr-23	8:40	4 hr 40 min	Coniston WWTP	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	635.00	disinfection
05	09-Apr-23	18:22	5 hr	Coniston WWTP	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	635.00	disinfection
06	11-Apr-23	12:50	127hr 25 min	Sudbury WWTP	1275 Kelly Lk Rd	PLT	Plant bypass: flow exceeds design capacity	none	juntion Creek	708Km3	disinfection
07	11-Apr-23	19:22	61 hrs	Lively wwtp	231 First Ave	Lively WWTP	Plant overflow	None	None	10,106.0	disinfection
08	25-Apr-23	13:00	7.5hrs	Beverly LS	966 Beverly	LS	Force main break	Receiving water	Lilly Creek		None
09	30-Apr-23	19:00	1.5hrs	Lively WWTP	20 MR.24	MH	Collection system overflow	None	NA		dilution
10	10-Apr-23	14:10	420.2 hr	Coniston WWTP	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	47,072.0	disinfection
11	30-Apr-23	18:18	56 hr	Lively wwtp	231 First Ave	Lively WWTP	Plant overflow	None	None	5,052.0	disinfection
13	30-Apr-23	17:40	80.4 hr	Sudbury WWTP	1275 Kelly Lk Rd	PLT	Plant bypass: flow exceeds design capacity	none	juntion Creek	436K	disinfection
16	20-Apr-23	13:55	360 hr	Wahnapiatae Lagoon	179 Lamonth St	Lagoon	Plant overflow	None	Wahnapiatae River	600.0	none
17	29-Apr-23	13:40	179 hr	Coniston WWTP	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	22,682.0	disinfection