



1st Quarter
2023

REVISED: 23-Feb-23

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Pit / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
01	13-Feb-23	9:00	1.25hrs	Walden WWTP	40 Vagini Crt	FM	Force main break	None	none			HTH shock-it	Equipment (failure)	none	
02	16-Feb-23	unknown	unknown	Capreol Lagoon	99 Lakeshore dr	Other	Collection system overflow	None	NA	<1m ³	est	HTH shock-it	Equipment (failure)	none	Volume estimated from time aware of leak