



2023

REVISED: 27-Jul-23

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m <sup>3</sup> )	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT
21	06-Jul-23	15:50	14.4 hrs	Coniston WWTP	121 Government Rd	Plt	Plant bypass: flow exceeds design capacity	None	Coniston Creek	1,829.0	est	Disinfection	Heavy rain
22	26-Jul-23	11:50	1.00	Sudbury WWTP	1034 Falconbridge Rd	other	Force main break	None	Junction Creek	72.0	est	none	Heavy rain