



2nd Quarter
2023

REVISED: 1-May-23

PLANT BYPASS / OVERFLOW LOG

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	LEVEL OF TREATMENT RECEIVED
12	01-May-23	13:45	48 hr	Government Rd LS	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	300.0	disinfection
14	02-May-23	1:30	12 hrs	Valley East WWTP	1862 Yorkshire Dr	PLT	Plant bypass: flow exceeds design capacity	None	Whitson River	2,500.0	Disinfection - Full Treatment
15	03-May-23	11:00	120 hrs	Capreol Lagoon	99 Lakeshore St	Lagoon	Plant overflow	None	N/A	250.0	Disinfection -Dechlorination
18	03-May-23	10:25	51 hr	Wahnapitae Lagoon	179 Lamonthe St	Lagoon	Plant overflow	None	Wahnapitae River	85.0	none
19	02-May-23	8:58	264.5 hr	Wahnapitae Lagoon	179 Lamonthe St	Lagoon	Plant overflow	None	Wahnapitae River	425.0	none
20	20-May-23	15:50	14 hr	Coniston WWTP	121 Government Rd	PLT	Plant bypass: flow exceeds design capacity	None	Coniston Creek	1,899.0	disinfection