



**PLANT BYPASS / OVERFLOW LOG**

**4th Quarter 2023**

REVISED: 15-Dec-23

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m <sup>3</sup> )	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE	Testmark
24	03-Oct-23	unknown	unknown	Valley East WWTP		plt	Plant overflow	None		1.0	est	To environment	Equipment (failure)		Stayed on city property and was cleaned up	514542
25	26-Oct-23	21:10	2 hrs	Government Rd LS	Coniston	LS	Collection system overflow	none	Coniston Creek	4.0	est	none	Heavy rain		to creek with HTH	517412
26	26-Oct-23	21:45	12 hr	Coniston WWTP	121 Government Rd	Plt	Plant bypass: flow exceeds design capacity	None	Coniston Creek	916.0	SCADA	Disinfection	Heavy rain			517249, 517252
27	20-Oct-23	19:00	1.00	Walden WWTP	257 Anderson Dr	Plt	Plant bypass	None	Simon Creek	UNK	NA	To environment	Equipment (failure)			No Samples Taken