

PLANT BYPASS / OVERFLOW LOG

REVISED:

#	DATE	TIME <small>(24H clock)</small>	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	COMMENTS / RELEVANCE
1	03-Jan-18	9:00	4.0 hrs	OTHER	990 Kingsway Sudbury	Other	Collection system overflow	Receptor not impacted	n/a	0.1	Est	1.0 kg of HTH	Sanitary sewer overflow	MINOR release of wastewater; disinfection procedures followed; no release to environment
2	11-Jan-18	19:00	12.0 hrs	Lively WWTP	Lively	Plt	Plant bypass: flow exceeds design capacity	Receptor not impacted	Meatbird Creek	600.0	Meas	5.0 kg of Cl2	Heavy rain	MINOR release of wastewater; disinfection procedures followed; no release to environment
3	27-Jan-18	12:20	9.0 hrs	Coniston WWTP	Coniston	Plt	Plant bypass: flow exceeds design capacity	Receptor not impacted	Coniston Creek	85.0	Meas	0.5 kg of Cl2	Maintenance	MINOR release of wastewater; disinfection procedures followed; no release to environment