

PLANT BYPASS / OVERFLOW LOG

REVISED: **June 5, 018**

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
12	02-May-18	17:35	8.5 hrs	Sudbury WWTP	Sudbury	Plt	Plant bypass: flow exceeds design	Receiving water	Junction Creek	4,250.0	46 kg of Cl2	Spring run-off	rain	MINOR release of wastewater;
13	01-May-18	8:30	132 hrs	Coniston WWTP	Coniston	Plt	Plant bypass: flow exceeds design	Receiving water	Coniston Creek	352.0	10 kg of Cl2	Spring run-off	rain	MINOR release of wastewater;
14	02-May-18	11:33	120 hrs	Lively WWTP	Lively	Plt	Plant bypass: flow exceeds design	Receiving water	Meatbird Creek	879.0	9.1 kg of Cl2	Spring run-off	rain	MINOR release of wastewater;
15	04-May-18	13:08	24 hrs	Azilda WWTP	Azilda	Plt	Plant bypass: flow exceeds design	Receiving water	Pilon Creek	796.5	4.5 kg of Cl2	Spring run-off	rain	MINOR release of wastewater;
16	04-May-18	19:50	2.8 hrs	Sudbury WWTP	Sudbury	Plt	Plant bypass: flow exceeds design	Receiving water	Junction Creek	1,400.0	17 kg of Cl2	Spring run-off	rain	MINOR release of wastewater;
17	04-May-18	22:30	5.5 hrs	Sudbury WWTP	Sudbury	Plt	Plant bypass	Receiving water	Junction Creek	23,545.0	51 kg of Cl2	Spring run-off	rain	Moderate release precipitated by warming and rain; flow fully treated.
18	07-May-18	9:00	2.0 hrs	OTHER	166 St. Louis St., Sudbury	Other	Collection system overflow	Receiving water	Junction Creek	0.4	n/a	Sanitary sewer overflow	blockage	MINOR release of wastewater;
19	03-May-18	0:00	96.0 hrs	Valley East WWTP	Hanmer	Plt	Plant bypass: flow exceeds design	Receiving water	Vermillion River	4,647.0	27 kg of Cl2	Spring run-off	rain	MINOR release of wastewater;
20	08-May-18	16:00	1.5 hrs	OTHER	840 Notre Dame Ave., Sudbury	Other	Collection system overflow	Receptor not impacted	n/a	1.0	n/a	Sanitary sewer overflow	blockage	MINOR release of wastewater;
21	24-May-18	11:30	2.5 hrs	OTHER	3219 Parkdale Cr., Val Caron	Other	Collection system overflow	Receptor not impacted	Whitson Creek	0.1	0.2 kg of HTH	Sanitary sewer overflow	blockage	MINOR release of wastewater;
22	26-May-18	0:33	2.5 hrs	Lively WWTP	Lively	Plt	Plant bypass: flow exceeds design	Receiving water	Meatbird Creek	857.3	1.1 kg of Cl2	Heavy rain	rain	MINOR release of wastewater;