

**PLANT BYPASS / OVERFLOW LOG**

REVISED: 3-Jan-20

#	DATE	TIME (24H clock)	DURATION	LOCATION	LOCATION DESCRIPTOR / ADDRESS	Plt / LS / Other	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m <sup>3</sup> )	Est or Meas?	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
73	Nov 4/19	23:15	4.5 hrs	Sudbury WWTP	Sudbury	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Junction Creek	4,600.0	Meas	24 kg of Cl2	Heavy rain	Heavy Rain	MINOR release of wastewater; disinfection procedures followed; no release to environment
74	Nov 4/19	16:25	22.0 hrs	Coniston WWTP	Coniston	Plt	Plant bypass: flow exceeds design capacity	Receiving water	Coniston Creek	764.0	Meas	6.4 kg of Cl2	Heavy rain	Heavy Rain	MINOR release of wastewater; disinfection procedures followed; no release to environment