



Waste Water Release Notification Reporting Log

Q1 2025

Release #	DATE	FACILITY NAME (use Dropdown)	ACTUAL RELEASE LOCATION	PLANT L/S Collection	TYPE OF OCCURRENCE (use Dropdown)	START TIME (24H clock)	DURATION (hrs)	VOL (m ³)	SENSITIVE RECEPTO R	REASON FOR EVENT	LEVEL OF TREATMENT RECEIVED
04	11-Feb-25	Walden WWTP	Oja Lift station	L/S	Force Main Break	11:00	15	2	None	Equipment	To Environment
05	25-Feb-25	Vermilion River LS	99 Lakeshore St Capreol	Collection	Force Main Break	9:20	1	10L/sec	None	Equipment	Disinfection
06	25-Feb-25	Vermilion River LS	99 Lakeshore St Capreol	L/S	Coll'n Sys Overflow	13:30	44.3	1835	None	Equipment	Disinfection