



Waste Water Release Notification Reporting Log

Q2 2025

Release #	DATE	REPORTED BY	FACILITY NAME (use Dropdown)	ACTUAL RELEASE LOCATION	PLANT L/S Collection	TYPE OF OCCURRENCE (use Dropdown)	START TIME (24H clock)	DURATION (hrs)	VOL (m ³)	SENSITIVE RECEPTOR	REASON FOR EVENT	LEVEL OF TREATMENT RECEIVED
<i>sample</i>	<i>11-Mar-24</i>	<i>James Larmer</i>	<i>Sudbury WWTP</i>	<i>Junction Creek</i>		<i>Plant By-Pass</i>	<i>16:30</i>	<i>13.5</i>	<i>24.6</i>	<i>None</i>	<i>Rain/Spring Run off</i>	
<u>11</u>	26-Apr-2025	Paul Pigozzo	Coniston WWTP	Coniston Creek	Plant	Plant By-Pass	12:50	8.66	900	None	Heavy Rain/Spring Run off	Disinfection
<u>14</u>	15-Apr-2025	Justin Medina	Wahnapiatae Lagoon	Wahnapiatae River	Plant	Plant Overflow	0848	1705	71	None	Rain/Run off/Equip	Disinfection
<u>15</u>	22-Apr-2025	Greg Pagan	Wahnapiatae Lagoon	Wahnapiatae River	Plant	Plant Overflow	0900	192	8	None	Rain/Run off/Equip	Disinfection