



Waste Water Release Notification Reporting Log

Q2 2026

Release # Link to File	DATE	REPORTED BY	FACILITY NAME (use Dropdown)	ACTUAL RELEASE LOCATION	PLANT L/S Collection	TYPE OF OCCURRENCE (use Dropdown)	START TIME (24H clock)	DURATION (hrs)	VOL (m³)	SENSITIVE RECEPTOR	REASON FOR EVENT	LEVEL OF TREATMENT RECEIVED
04	3-Apr-26	Greg Pagan	Coniston WWTP	Coniston Creek	Plant	Plant By-Pass	01:03	103.00	9931	None	Spring Run Off	Disinfection
05	3-Apr-26	Paul Pigozzo	Lively WWTP	Lively Plant	Plant	Plant Overflow	04:30	2.50	50	None	Heavy Rain/Spring Run off	Disinfection
06	9-Apr-26	Pierre Lacroix	Lively WWTP	Lively Plant	Plant	Plant Overflow	09:00	4.00	504	None	Power Failure	Disinfection
07	3-Apr-26	Dennis Parolin	Lively WWTP	Lively Plant	Plant	Plant By-Pass	01:58	101.45	24937	None	Spring Run Off	Disinfection
08	9-Apr-26	Greg Pagan	Coniston WWTP	Contact Chamber	Plant	Plant By-Pass	0945	248.50	18638	None	Heavy Rain/Spring Run off	Disinfection
09	13-Apr-26	Justin Miden	Sudbury WWTP	Horobin LS	Collection	Coll'n Sys Overflow	2114	133.55	280000	None	Spring Run Off	Disinfection
10	13-Apr-26	Bradley Lebel	Lively WWTP	Anderson LS	Collection	Coll'n Sys Overflow	1615	3.75	602	None	Spring Run Off	Disinfection
11	14-Apr-26	Greg Pagan	Garson-Coniston LS	Government Rd LS , Coniston Creek	Collection	Plant Overflow	1310	128.75	14400	None	Spring Run Off	Disinfection
12	16-Apr-26	Pierre Denis	Valley East WWTP	Hillsdale LS	Collection	Coll'n Sys Overflow	1400	162.00	35000	Receiving Water	Spring Run Off	Disinfection
13	9-Apr-26	Pierre Lacroix	Lively WWTP	Meatbird Creek	Plant	Plant By-Pass	1630	256.50	40652	None	Spring Run Off	Disinfection
14	03-Apr-26	Stephen Bouthillette	Sudbury WWTP	Contact Chamber	Plant	Plant By-Pass	0200	438.00	1759563	None	Heavy Rain/Spring Run off	Disinfection
15	17-Apr-26	Jeff Vanderydt	Azilda WWTP	Landry LS	Collection	Coll'n Sys Overflow	1800	15.00	1800	None	Heavy Rain/Spring Run off	Disinfection
16	14-Apr-26	Marc Laflamme	Chelmsford WWTP	Chelmsford WWTP	Plant	Plant By-Pass	0730	204.92	5937	None	Heavy Rain/Spring Run off	Disinfection
17	29-Apr-26	Crystal Ribey	Lively WWTP	Meatbird Creek	Plant	Plant By-Pass	0000	9.00	1087	None	Power Failure	Disinfection
18	28-Apr-26	Greg Pagan	Coniston WWTP	Coniston Creek	Plant	Plant By-Pass	14:30	19.00	1216		Spring Run Off	Disinfection
19	14-Apr-26	Chase Vaillancourt	Valley East WWTP	Swale in Yard to Whitson Creek	Plant	Plant Overflow	18:30	98.75	2227	None	Spring Run Off & Equipment failure	Disinfection
20	16-Apr-26	Kathleen Gillis	Valley East WWTP	Vermillion River	Plant	Plant By-Pass	20:50	74.08	11666	None	Spring Run Off	Disinfection
21	16-Apr-26	Kathleen Gillis	Valley East WWTP	Swale in Yard to Whitson Creek	Plant	Plant Overflow	21:25	72.50	11666	None	Spring Run Off	Full Treatment
22	26-Apr-26	Pierre Denis	Capreol Lagoon	South Cell	Plant	Plant By-Pass	10:00	65.00	48976	None	Spring Run Off	Raw Sewage
23	26-Apr-26	Jesse Lefebvre	Dowling WWTP		Plant	Plant By-Pass	06:37	269.6	30652	None	Spring Run Off	Disinfection
24	27-Apr-26	Christina Duff	Dowling WWTP	Onaping River	Plant	Plant By-Pass	17:52	70.13	5071	None	Spring Run Off & Equipment failure	Disinfection
25	28-Apr-26	Chase Vaillancourt	Valley East WWTP	Swale in Yard to Whitson Creek	Plant	Plant Overflow	10:00	1.50	100	None	Spring Run Off & Equipment failure	Full Treatment
27	28-Apr-26	Paul Pigozzo	Helene LS	Whitson Creek	L/S	Coll'n Sys Overflow	13:00	2.00	360	None	Heavy Rain/Spring Run off	Disinfection
28	25-Apr-26	Paul Pigozzo	Helene LS	Whitson Creek	L/S	Coll'n Sys Overflow	23:00	4.3	660			Disinfection
29	20-Apr-26	Greg Pagan	Wahnapiatae Lagoon	Wahnapiatae Creek	Other	Plant Overflow	08:50	850	225			
30	20-Apr-26	Greg Pagan	Wahnapiatae Lagoon	Wahnapiatae Creek	Other	Plant Overflow	08:35	432	180			
31	19-Apr-26	Heidi Chartier	Capreol Lagoon	Ground/berm	Plant	Plant Overflow	10:00	16.5	1,718.75	None	Spring Run Off	Disinfection
32	17-Apr-26	Heidi Chartier	Chelmsford WWTP	Belanger LS - Whitson River	L/S	Coll'n Sys Overflow	19:37	28.66	3,442	None	Spring Run Off	Disinfection
33	18-Apr-26	Jessica Brunette	Valley East WWTP	Helene LS - Whitson Creek	L/S	Coll'n Sys Overflow	00:05	64	11,505	None	Spring Run Off	Disinfection
34	28-Apr-26	Jessica Brunette	Azilda WWTP	Landry LS - creek outlet to Whitewater	L/S	Coll'n Sys Overflow	10:00	11.6	140	None	Spring Run Off	Disinfection
35	28-Apr-26	Heidi Chartier	Coniston WWTP	Government Rd, Coniston Creek	Collection	Plant Overflow	09:30	8	960	None	Spring Run Off	Disinfection
36	14-Apr-26	Rod MacDonald	Lively WWTP	Anderson LS - Meatbird Creek	L/S	Coll'n Sys Overflow	08:12	148.80	6984		Spring Run Off	Disinfection
37	14-Apr-26	Andre Frappier	Sudbury WWTP	Selkirk LS	L/S	Coll'n Sys Overflow	10:15	150	17,970		Spring Run Off	Disinfection
38	14-Apr-26	Amber Campbell	Azilda WWTP	Landry LS	L/S	Coll'n Sys Overflow	10:00	17.5	1896		Spring Run Off	Disinfection