



Waste Water Release Notification Reporting Log

Q2 2026

Release # Link to File	DATE	REPORTED BY	FACILITY NAME (use Dropdown)	ACTUAL RELEASE LOCATION	PLANT L/S Collection	TYPE OF OCCURRENCE (use Dropdown)	START TIME (24H clock)	DURATION (hrs)	VOL (m ³)	SENSITIVE RECEPTOR	REASON FOR EVENT	LEVEL OF TREATMENT RECEIVED
40	10-Jun-26	Rod MacDonald	Coniston WWTP	Coniston Creek	Plant	Plant By-Pass	7:50	8.5	905		Heavy Rain/Spring Run off	Disinfection
41	10-Jun-26	Rod MacDonald	Sudbury WWTP	Junction Creek	Plant	Plant By-Pass	9:00	13.5	66817		heavy rain	Disinfection
42	10-Jun-26	Bradley Lebel	Government Rd LS	Coniston Creek	Collection	Plant By-Pass	09:45	2	105		heavy rain	Disinfection