



Waste Water Release Notification Reporting Log

Q4 2025

Release #	DATE	REPORTED BY	FACILITY NAME (use Dropdown)	ACTUAL RELEASE LOCATION	PLANT L/S Collection	TYPE OF OCCURRENCE (use Dropdown)	START TIME (24H clock)	DURATION (hrs)	VOL (m ³)	SENSITIVE RECEPTOR	REASON FOR EVENT	LEVEL OF TREATMENT RECEIVED	RECEIVING STREAM ID
26	10-Dec-25	Marc Laflamme	Chelmsford WWTP	Yard/Bypass Manhole	Plant	Plant Overflow	09:15	0.08	5	None	Equipment	To Environment	Whitson
27	22-Dec-25	Conner Bradley	Wahnapitae Lagoon	Normal discharge location	Plant	Plant Overflow	09:25	72	3	None	Maintenance	To Environment	Wahnapitae River
28	4-Dec-2025	Paul Cipriani	Wahnapitae Lagoon	Normal discharge location	Plant	Plant Overflow	10:30	312	13	None	Maintenance	To Environment	Wahnapitae River