409 MUNI **CONSTRUCTION SPECIFICATION FOR CLOSED-CIRCUIT TELEVISION (CCTV) INSPECTION OF PIPELINES**

409.07.05 **CCTV Inspection**

409.07.05.01 **General**

DELETE the first paragraph and REPLACE with the following:

CCTV Camera inspections shall be done by the Contractor in accordance with the pipe condition coding practices as outlined in Pipeline Assessment and Certification Program (PACP®) Canadian Edition including CSA PLUS 4012 TECHNICAL GUIDE Visual inspection of sewer pipe or as specified in the Contract Document.