

802 MUNI CONSTRUCTION SPECIFICATION FOR TOPSOIL**802.07.03 Placement of Topsoil****DELETE and ADD in the following:**

Topsoil shall be spread to a uniform depth of 100 mm on designated areas and up to the subgrade elevation on the roadway front slope.

Soil from swamps or muskeg areas, when used in place of topsoil shall be spread to a uniform depth of 150 mm, with no woody material protruding above the surface.

Imported topsoil must be approved by the General Manager prior to arrival on site.