

**409 MUNI CONSTRUCTION SPECIFICATION FOR CLOSED-CIRCUIT TELEVISION (CCTV)
INSPECTION OF PIPELINES**

409.07.05 CCTV Inspection

409.07.05.01 General

DELETE the first paragraph and REPLACE with the following:

CCTV Camera inspections shall be done by the Contractor in accordance with the pipe condition coding practices as outlined in Pipeline Assessment and Certification Program (PACP®) Canadian Edition including CSA PLUS 4012 TECHNICAL GUIDE Visual inspection of sewer pipe or as specified in the Contract Document.

409-01