

WASTEWATER STEWARDSHIP REPORT - 2015 3rd QUARTER

| DATE | TIME (24H clock) | DURA- TION | LOCATION | LOCATION DESCRIPTOR | TYPE OF OCCURRENCE | SENSITIVE RECEPTOR | RECEIVING STREAM ID | VOL (m ³) | LEVEL OF TREATMENT RECEIVED | REASON FOR EVENT | OUTSIDE INFLUENCES | COMMENTS / RELEVANCE |
|-----------|------------------------|---------------|-------------|-----------------------------------|--|-----------------------|------------------------|-----------------------|-----------------------------------|-------------------------|-----------------------|----------------------|
| 04-Aug-15 | 16:15 | 2.0 hrs | OTHER | 1133 Lasalle Blvd@Notre Dame Ave. | Collection system overflow | Receptor not impacted | Junction Creek | 2 | 0.5 kg of HTH | Sanitary sewer overflow | n/a | |
| 21-Aug-15 | 8:00 | 2.5 hrs | Lively WWTP | Lively | Plant bypass: flow exceeds design capacity | Receiving water | Meatbird Creek | 60 | 2.5 kg Cl2 | Heavy rain | Heavy Rainfall | |
| 21-Aug-15 | 8:10 | 8hrs 20 mins | Walden WWTP | | Plant bypass: flow exceeds design capacity | Receiving water | Junction Creek | 983 | 0.45 kg Cl2 | Heavy rain | Heavy Rainfall | |