

WASTEWATER STEWARDSHIP REPORT - 2015 1st QUARTER

REVISED: 7-Apr-15

DATE	TIME (24H clock)	DURA- TION	LOCATION	LOCATION DESCRIPTOR	TYPE OF OCCURRENCE	SENSITIVE RECEPTOR	RECEIVING STREAM ID	VOL (m ³)	LEVEL OF TREATMENT RECEIVED	REASON FOR EVENT	OUTSIDE INFLUENCES	COMMENTS / RELEVANCE
02-Mar-15	10:00	0.5 hrs	Chelmsford WWTP	Chelmsford	Spill (environmental)	Receptor not impacted	Whitson River	1.0	1.0 kg of HTH	Equipment (failure)	None	MINOR release of wastewater contained on site; disinfection procedures followed
06-Mar-15	10:45	9.25 hrs	Levack WWTP	Montgomery St, Levack	Collection system overflow	Receiving water	Moose Creek	0.4	Not Applicable	Maintenance	None	MINOR release of wastewater contained on site
09-Mar-15	12:00	0.25 hrs	Chelmsford WWTP	Chelmsford	Spill (environmental)	Receptor not impacted	Whitson River	1.0	Not Applicable	Equipment (failure)	None	MINOR release of wastewater contained on site